

**STATE OF NORTH CAROLINA  
UTILITIES COMMISSION  
RALEIGH**

In the Matter of )  
2025 Biennial Consolidated Carbon Plan and )  
Integrated Resource Plans of Duke )  
Energy Carolinas, LLC, and Duke ) Docket No. E-100, Sub 207  
Energy Progress, LLC, Pursuant to )  
N.C.G.S. § 62-2(a)(3a), 62-110.1, 62-110.9, )  
and Commission Rule R8-60A )

**DIRECT TESTIMONY OF  
JOHN MICHAEL HAGERTY**

**ON BEHALF OF  
CAROLINAS CLEAN ENERGY BUSINESS ASSOCIATION**

**MARCH 30, 2026**

**TABLE OF CONTENTS**

**I. Review of Duke IRP Modeling Approach and Assumptions .....9**

**II. Review of Duke IRP Modeling Results .....38**

**III. REVIEW OF DUKE’S TRANSMISSION PLANNING PROCESS.....53**

**IV. SUPPORT FOR CEBA’S PROPOSED CLEAN CUSTOMER TARIFF .....70**

STATE OF NORTH CAROLINA  
UTILITIES COMMISSION  
RALEIGH

DOCKET NO. E-100, SUB 207

BEFORE THE NORTH CAROLINA UTILITIES COMMISSION

In the Matter of	)	
2025 Biennial Consolidated Carbon Plan	)	<b>DIRECT TESTIMONY OF JOHN</b>
and Integrated Resource Plans of Duke	)	<b>MICHAEL HAGERTY ON BEHALF</b>
Energy Carolinas, LLC, and Duke	)	<b>OF CAROLINAS CLEAN ENERGY</b>
Energy Progress, LLC, Pursuant to	)	<b>BUSINESS ASSOCIATION</b>
N.C.G.S. §§ 62-2(a)(3a), 62-110.1, 62-	)	
110.9, and Commission Rule R8-60A	)	

1     **Q: PLEASE STATE YOUR NAME, JOB TITLE, EMPLOYER AND**  
2     **BUSINESS ADDRESS.**

3     A: My name is John Michael Hagerty. I am a Principal at The Brattle Group. My  
4     business address is 1800 M Street Northwest, Washington, DC 20036.

5     **Q: PLEASE SUMMARIZE YOUR EDUCATIONAL BACKGROUND AND**  
6     **PROFESSIONAL QUALIFICATIONS.**

7     A: I earned an M.S. in Technology and Policy from the Massachusetts Institute of  
8     Technology and a B.S. in Chemical Engineering from the University of Notre  
9     Dame. I have 13 years of experience at The Brattle Group in utility and electric  
10    power industry planning and regulatory analysis, including utility resource  
11    planning, transmission planning, valuation of renewable energy, storage, and  
12    transmission assets, wholesale market design to achieve resource adequacy  
13    requirements, and optimized approaches to economy-wide deep decarbonization.

14             Since 2021, I have analyzed and reviewed the future resource needs in the  
15    Duke Energy Carolinas (“DEC”) and Duke Energy Progress (“DEP”) service

16 territories (collectively referred to as “Duke”) as an intervenor in the resource  
17 planning dockets before the Commission. I have also actively participated since  
18 2023 in the Carolinas Transmission Planning Collaborative (“CTPC”)  
19 transmission planning studies, including the 2023 Public Policy Study and the  
20 2025 Multi-Value Strategic Transmission (“MVST”) planning process.

21 In addition to my experience in North Carolina, I have experience  
22 supporting generation developers, transmission developers, electric utilities, state  
23 regulators and agencies, and regional transmission operators with transmission  
24 planning processes and benefits analyses in all of the planning regions across the  
25 country, including CAISO, ERCOT, SPP, MISO, NYISO, PJM and ISO-NE. I  
26 authored a report on the regional transmission planning completed by the  
27 Southeastern Regional Transmission Planning (“SERTP”) process, in which Duke  
28 participates, and opportunities to improve its regional planning approach through  
29 FERC Order No. 1920. I am also currently involved in the Florida Reliability  
30 Coordinating Council stakeholder process for compliance of Order No. 1920.

31 I have participated in generation resource planning across the country and  
32 submitted testimony, reports, or stakeholder comments to the respective state-  
33 level commissions or applicable boards in California, Maine, Wisconsin,  
34 Tennessee, and Kentucky. My work in generation resource planning includes  
35 work for electric utilities completing the resource planning studies as well as  
36 renewable energy trade groups and generation developers intervening in the  
37 planning process and related dockets.

38                   Recently, I have worked with both generation developers and hyperscalers  
39                   in seeking opportunities for interconnecting new data centers to the power system  
40                   as efficiently as possible while meeting the resource adequacy and transmission  
41                   security needs of the system.

42                   A copy of my CV is attached as **Exhibit 1**.

43                   **Q: WHAT ARE YOUR RESPONSIBILITIES IN YOUR CURRENT**  
44                   **POSITION?**

45                   A: I provide economic and financial analysis for a broad set of clients in the electric  
46                   utility industry that are mostly focused on the drivers for new generation and  
47                   transmission infrastructure investments, including renewable energy and gas-fired  
48                   generation resources as well as transmission assets. As noted above, my clients  
49                   include electric utilities, renewable energy and storage developers, transmission  
50                   developers, system operators, environmental organizations, and state agencies.

51                   **Q: HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE COMMISSION?**

52                   A: Yes, I testified before the North Carolina Utility Commission in the 2022 and  
53                   2024 Duke resource planning dockets, specifically Docket No. E-100, Sub 179  
54                   and Docket No. E-100, Sub 190. I also presented on behalf of the Carolinas Clean  
55                   Energy Business Association in the Large Load Technical Conference on October  
56                   14, 2025 in Docket No. E-100, Sub 208.

57                   **Q: ON WHOSE BEHALF ARE YOU TESTIFYING?**

58                   A: The Carolinas Clean Energy Business Association (CCEBA).

59                   **Q: ARE YOU SUBMITTING ANY EXHIBITS WITH YOUR TESTIMONY?**

60                   A: Yes, I am submitting the following exhibits:

- 61 ▶ **Exhibit 1:** CV of John Michael Hagerty.
- 62 ▶ **Exhibit 2:** Astrape Consulting, Duke Energy Carolinas and Duke Energy
- 63 Progress Solar Integration Service Charge (SISC) Study, November 1, 2023;
- 64 ▶ **Exhibit 3:** Affidavit of Aaron Melda and Lonnie Bellar (Overview Affidavit),
- 65 Attachment B to the SEEM Transmittal Letter;
- 66 ▶ **Exhibit 4:** Potomac Economics, Annual Audit Report on the Southeast
- 67 Energy Exchange Market, June 2, 2025;
- 68 ▶ **Exhibit 5:** CAISO, Western Energy Imbalance Market Benefits Report,
- 69 Fourth Quarter 2025, February 13, 2026;
- 70 ▶ **Exhibit 6:** GDS Associates, Inc., Inspection and Examination Report of Duke
- 71 Energy Carolinas, LLC and Duke Energy Progress, LLC: December 2022
- 72 Winter Storm Outages and Blackouts, Docket No. ND-2023-1-E, August 25,
- 73 2023;
- 74 ▶ **Exhibit 7:** CTPC, 2024 Multi-Value Strategic Transmission (MVST) Study,
- 75 January 17, 2025.
- 76 ▶ **Exhibit 8:** Hagerty, et al., Modernizing Southeast Grid Investments: How
- 77 Enhanced Regional Transmission Planning Supports a Growing Economy,
- 78 April 2, 2025.

79 **Q: WHAT IS THE PURPOSE OF YOUR DIRECT TESTIMONY?**

80 A: The purpose of my testimony is to: (1) review Duke's IRP modeling assumptions

81 and approach as it relates to solar resources, (2) review the results of the IRP

82 modeling and the value of solar to the Duke system, (3) summarize recent

83 transmission planning studies completed by Duke to reduce costs, increase the

84 ability to serve future demand, and support new generation resources, and (4)  
85 discuss ways of addressing large customers with clean energy goals and  
86 requirements.

87 **Q: PLEASE PROVIDE A BRIEF SUMMARY OF YOUR CONCLUSIONS.**

88 A: My testimony reaches the following conclusions:

- 89 ▶ Solar resources continue to be a prudent, cost-effective addition to the Duke  
90 system, with Duke's modeling showing the need to add 4 GW of new solar by  
91 2034 and over 10 GW by 2040 in the Near-Term Action Plan.
- 92 ▶ Duke's assumptions for the costs and operating characteristics of solar  
93 resources are generally reasonable and comprehensive, with no hidden costs  
94 unaccounted for in the modeling.
- 95 ▶ However, two assumptions in Duke's modeling tend to underestimate the  
96 value of solar, including: (1) the failure to capture the full value of battery  
97 storage as an operating asset in conjunction with solar; and (2) the inability to  
98 export excess solar to neighboring systems.
- 99 ▶ Other markets in the U.S. already generate more from solar and wind  
100 resources than Duke's forecasts for 2035; for example, the 2025 generation  
101 mix of the ERCOT market in Texas included 14% of total generation from  
102 solar and an additional 23% from wind resources;
- 103 ▶ Solar provides critical value to Duke ratepayers by serving as a hedge against  
104 natural gas price volatility and supply infrastructure risks, a significant factor  
105 as Duke's reliance on gas generation is projected to [REDACTED] through 2035.

- 106 ▶ Duke’s modeling demonstrates across a wide range of future system  
107 conditions that more solar capacity is cost-effective to the future Duke system  
108 than identified in the Preliminary Base scenario.
- 109 ▶ Duke has a limited set of resource options in the near-term for meeting a  
110 significantly higher projection of load growth both in terms of total annual  
111 energy demand and peak demand requirements.
- 112 ▶ Solar and storage are essential resources for meeting higher load growth  
113 scenarios, as Duke's modeling shows these resources are the primary additions  
114 needed when load growth exceeds the limits of building new gas combined  
115 cycle plants.
- 116 ▶ Proactive transmission planning through the CTPC’s MVST process will  
117 reduce ratepayer costs, streamline the interconnection process, and provide  
118 more accurate inputs for resource planning.
- 119 ▶ By contrast, relying primarily on the interconnection process to identify  
120 transmission upgrades results in higher costs to customers; proactive planning  
121 should identify least-regrets upgrades that provide cost effective reliability  
122 benefits across a range of future scenarios.
- 123 ▶ The clean customer tariff proposed by witnesses Levitas and Barua for the  
124 Clean Energy Buyers Association (“CEBA”) is persuasive and their proposal  
125 would enhance the ability to meet large customer demand for clean energy  
126 resources while limiting risk to other ratepayers.

127 **Q: CAN YOU PLEASE SUMMARIZE YOUR RECOMMENDATIONS TO**  
128 **THE COMMISSION?**

- 129 A: Yes, I have the following recommendations for the Commission to consider:
- 130 1. The Commission should increase the solar procurement targets in the Duke
- 131 Near-Term Action Plan from an average of 770 MW per year for the 2026-
- 132 2028 RFPs to at least 1,000 MW per year to ensure it has sufficient resources
- 133 to serve the High Load case.
- 134 2. Duke should update its modeling to reflect the full value of battery storage.
- 135 Duke can do so by either better capturing volatility in the marginal costs of
- 136 energy and the reliability services value of storage within its model, or by
- 137 calculating the estimated incremental value of storage not captured by the
- 138 EnCompass software and incorporating those results into the model.
- 139 3. Duke should improve its representation of transactions with its neighboring
- 140 systems in its model to better account for the availability and value of non-
- 141 firm transactions in the most cost-effective resource portfolio.
- 142 4. The Commission should require Duke to study the effectiveness of the
- 143 Southeast Energy Exchange Market (“SEEM”) in enabling cost-saving
- 144 transactions with neighboring systems and identify improvements such as an
- 145 energy imbalance market that could unlock additional savings based on
- 146 experience in the non-RTO portions of the western U.S.
- 147 5. I recommend the following for the next MVST study:
- 148 a. Given the uncertainty in load projections identified in the current
- 149 resource planning study, the next MVST scenarios should include at
- 150 least two future load growth scenarios rather than one;

- 151                   b. The CTPC should summarize constraints identified in the base case  
152                   production cost model, similar to the results shared for the reliability  
153                   models, and present the costs incurred by those binding constraints  
154                   during the needs assessment phase;
- 155                   c. The CTPC should validate its production cost model using a recent  
156                   historical year's load, generation resource mix, renewable energy  
157                   generation, and natural gas prices to calibrate how well the model  
158                   replicates the results of the real-world system, including generation  
159                   mix, renewable curtailments, and total production costs; and,
- 160                   d. The CTPC should present more detail of its analysis of each of the  
161                   benefits of transmission solutions, so that stakeholders can understand  
162                   the impact of each solution to the system compared to alternatives.
- 163           6. The Commission should continue to review Duke's transmission planning and  
164           interconnection processes to identify opportunities for improving the processes  
165           and reducing costs to ratepayers while maintaining system reliability.
- 166           7. The Commission should actively participate in the development of the SERTP  
167           Order No. 1920 compliance filing and urge Duke to leverage its experience with  
168           the MVST process to support a proactive, multi-value, scenario-based planning  
169           process at SERTP that exceeds the requirements of Order No. 1920 and supports  
170           cost-saving regional transmission upgrades across the Southeast.
- 171           8. The Commission should find that the existing GSA Choice program does not  
172           provide the additionality that large customers need, and has therefore largely  
173           failed to serve its intended purpose. I recommend that the Commission direct

174 Duke to file an application for approval of a new clean customer tariff for  
175 commercial and industrial customers consistent with the six elements described in  
176 CEBA's testimony and endorsed in my testimony.

177 **I. REVIEW OF DUKE IRP MODELING APPROACH AND ASSUMPTIONS**

178 **Q: DID YOU REVIEW DUKE'S MODELING FOR ITS 2025 IRP,**  
179 **INCLUDING THE ASSUMPTIONS FOR NEW SOLAR RESOURCES?**

180 A: Yes, I reviewed Duke's approach and assumptions for modeling its future power  
181 system for the 2025 IRP including the appendices and several responses to data  
182 requests with a particular focus on the assumptions for new solar photovoltaic  
183 resources (which I will refer to as "solar" in the rest of my testimony).

184 **Q: WHAT INPUT ASSUMPTIONS ARE NEEDED TO ACCURATELY**  
185 **CAPTURE THE COST AND VALUE OF SOLAR RESOURCES IN**  
186 **DUKE'S IRP MODELING?**

187 A: There are several modeling inputs that are important for accurately capturing the  
188 cost and value of solar to the Duke system. The key input assumptions for  
189 modeling the cost of solar to the system include: (1) the costs of installing new  
190 solar resources (often referred to as the "capital costs"), (2) the costs of building  
191 necessary transmission network upgrades for interconnecting the solar resources,  
192 (3) the operations and maintenance costs ("O&M") once the resource has been  
193 built, (4) federal tax credits applicable to the solar resource, (5) the hourly  
194 generation profile of the solar resource, (6) the contribution of the solar resource  
195 to meeting Duke's planning reserve requirements (which is quantified based on  
196 the resource's Effective Load Carrying Capability, or "ELCC"), and (7) annual

197 build limits. In addition, Duke assumes that the addition of renewable energy  
198 resources, including solar and wind resources, will increase its need for operating  
199 reserves.

200 In addition to the assumptions specific to solar resources, the value of  
201 solar to the Duke system is dependent on the growth and shape of system load;  
202 the cost, availability and operating characteristics of alternative sources of  
203 generation and storage; commodity fuel prices; natural gas infrastructure costs  
204 and availability; and compliance with regulatory and statutory emissions  
205 requirements.

206 **Q: ARE THE INPUT ASSUMPTIONS SPECIFIC TO THE SOLAR**  
207 **RESOURCES GENERALLY REASONABLE?**

208 A: Yes, at a high level the Duke modeling of solar resources reflects reasonable  
209 assumptions concerning the costs and operating characteristics of solar. Several  
210 assumptions have changed significantly since the last Duke resource planning  
211 study including higher capital costs, the end of federal tax credits for renewable  
212 energy resources that start construction after July 2026, and the removal of the  
213 North Carolina interim GHG emissions target for the early 2030s. The solar build  
214 limits of 1,200 MW per year in the early 2030s, while lower than the 1,800 MW  
215 per year recommended by CCEBA in the past, are reasonable given recent  
216 macroeconomic and system level changes impacting the Duke portfolio selections

217 and the impact of proactive transmission planning to reduce interconnection  
218 challenges in the future.<sup>1</sup>

219           Importantly, the assumptions are comprehensive in terms of solar costs,  
220 generation profiles, and uncertainty in analyzing the impacts and value of solar on  
221 the system. There are no “hidden” costs of solar that the Duke modeling does not  
222 capture. Instead, several assumptions within the modeling completed for the IRP  
223 tend to underrepresent the value of solar.

224 **Q: YOU MENTIONED THAT SOME COSTS ARE HIGHER THAN IN THE**  
225 **PAST IRP STUDIES. WHAT IS DRIVING THOSE HIGHER COSTS AND**  
226 **HOW DO THE COST INCREASES FOR SOLAR COMPARE TO OTHER**  
227 **RESOURCES?**

228 A: The costs of all generation resources have increased over the past several years  
229 due to general escalation of costs across the economy, higher labor costs, interest  
230 rates, the effect of tariffs, and tighter supply chains for meeting the growing  
231 demand for new generation and electrical equipment across the country to serve  
232 significant load growth. The costs of other resources, including gas CC, gas CT,  
233 and battery storage, have also increased for many of the same reasons. Overall the  
234 assumed capital costs for solar and other generation resources in the Duke IRP  
235 modeling are in a reasonable range based on my experience modeling power  
236 system across the country and input from current solar developers.

---

<sup>1</sup> Verified Petition for Approval of 2025 Carbon Plan and Integrated Resource Plan of Duke Energy Carolinas LLC and Duke Energy Progress LLC, Docket E-100, Sub 207, October 1, 2025, (“Duke IRP”) Appendix C: Quantitative Analysis, p. 27.

237                   Importantly, the future costs of solar projects may not be the same as  
238 assumed in Duke’s resource planning study. Duke’s sensitivity cases for higher  
239 and lower costs of new solar resources are thus important for understanding the  
240 impacts of higher and lower capital costs on optimal solar resource volumes. The  
241 results of those cases show that 30% higher solar costs have limited impact on  
242 solar additions, reducing 2040 solar by just 225 MW from the Preliminary Base  
243 scenario. On the other hand, the scenario with 30% lower solar costs identifies a  
244 need for significantly more solar, increasing solar additions by 4,000 MW over  
245 the Preliminary Base scenario.<sup>2</sup>

246       **Q: DOES DUKE ACCOUNT FOR THE COST OF TRANSMISSION**  
247       **NETWORK UPGRADES FOR INTERCONNECTING SOLAR AND**  
248       **OTHER RESOURCES?**

249       **A:** Yes, Duke includes a transmission network upgrade cost for each resource type in  
250 its modeling, and that value is added to the installed cost of the generation  
251 resource itself. As Duke notes, “[t]his cost adder is a proxy for upgrading the  
252 transmission network for reliable power transmission from the resource into the  
253 networked transmission system.”<sup>3</sup> For solar, Duke assumed the cost for network  
254 upgrades is \$190-200/kW, depending on the utility operating company territory.<sup>4</sup>  
255 Notably, the network upgrade costs for solar are lower than the network upgrade  
256 cost for new gas CC, gas CT, and nuclear resources, as shown in Figure 1 below.  
257 Thus, not only does Duke account for transmission upgrades for new solar

---

<sup>2</sup> Duke IRP, Chapter 3: Portfolio Development & Evaluation, Table 3-5, p. 6.

<sup>3</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 37.

<sup>4</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 37.

258 generation and other resources in its modeling, the network upgrade costs for Gas  
 259 CC and CT are higher than for Solar and Solar Paired With Storage (“SPWS”).

260 **FIGURE 1: NETWORK UPGRADE COSTS BY RESOURCE TYPE (DEC) (\$/KW)**



261

262 Source: Duke IRP, Appendix C: Quantitative Analysis, p. 37.

263 **Q: WHAT IS THE BASIS FOR THE NETWORK UPGRADE COSTS**  
 264 **ASSUMED IN THE DUKE IRP MODELING?**

265 A: Duke estimates the network upgrade costs based on recently completed generator  
 266 interconnection studies and results from the ongoing 2024 Definitive  
 267 Interconnection System Impact Study (“DISIS”) Phase II Cluster study.<sup>5</sup>

268 **Q: IS THERE ANY REASON TO BELIEVE THAT THERE ARE MISSING**  
 269 **CATEGORIES OF NETWORK UPGRADE COSTS NOT ASSUMED IN**  
 270 **DUKE’S MODELING?**

271 A: No.

272 **Q: WHY NOT?**

273 A: Duke has relied on the most recent market data for projects currently in  
 274 development for estimating the costs of network upgrades.

---

<sup>5</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 37.

275 **Q: DO YOU HAVE ANY REASON TO BELIEVE THAT FUTURE**  
276 **NETWORK UPGRADE COSTS FOR INTERCONNECTING SOLAR**  
277 **WILL BE LOWER THAN THE RECENT COST DATA INDICATES?**

278 A: Yes.

279 **Q: WHY?**

280 A: The network upgrade costs are based on recent information from interconnection  
281 costs of each resource type. I expect future network upgrades costs likely will  
282 decrease in future years as Duke, through the CTPC, implements proactive  
283 approaches to planning its future system, including the Red Zone Economic  
284 Projects (“RZEP”) and MVST projects. These projects are being pursued for a  
285 variety of economic and reliability reasons, but one benefit of these forward-  
286 looking planning approaches will be reduced network upgrade costs and reduced  
287 delays for new generation. As I noted above, this is important because lower solar  
288 capital costs have a significant impact on solar additions.

289 I explain in more detail later in my testimony the approaches that Duke is  
290 taking to reduce the costs and increase the value of transmission additions for  
291 serving new load and accessing lower cost resources.

292 **Q: EARLIER YOU MENTIONED THAT THE SOLAR GENERATION**  
293 **PROFILE IS AN IMPORTANT ASSUMPTION FOR MODELING SOLAR**  
294 **RESOURCES. PLEASE EXPLAIN.**

295 A: The solar generation profile provides the IRP models an input of the hourly  
296 amount of electricity that will be generated by each solar resource. The amount of

297 solar output differs by the hour of day and throughout the year, but also from  
298 hour-to-hour and day-to-day based on projected weather conditions.

299 **Q: DOES THE DUKE IRP MODELING ACCOUNT FOR THE NATURAL**  
300 **VARIATION IN SOLAR GENERATION?**

301 A: Yes. I reviewed the assumed solar generation profiles that Duke includes in its  
302 IRP modeling for new solar resources and found that they accurately account for  
303 variations in solar output.<sup>6</sup> Duke completes an extensive analysis of historical  
304 solar generator production across North Carolina and South Carolina to develop  
305 these profiles.<sup>7</sup> The solar generation profiles incorporate variations in: (1) hourly  
306 generation due to the daily cycle of sunlight, (2) daily generation due to day-to-  
307 day variations in cloud cover, and (3) monthly generation due to seasonal shifts in  
308 solar irradiance. These hourly, daily, and monthly variations in generation are  
309 mostly predictable at the portfolio level, such that Duke is able to forecast solar  
310 production accurately and integrate that production with the efficient dispatch of  
311 other generation resources. Duke assumes the same profiles for each future year,  
312 which does not capture annual variations in total solar irradiance, but annual  
313 variation tends to be relatively low with most years within 2-3% of the average.

314 I created several figures to demonstrate the variation in solar generation  
315 across different timescales assumed in Duke's resource planning models. [REDACTED]


---

<sup>6</sup> I reviewed the solar generation profiles provided by Duke in response to PS DR 7-2 in the file 1.7.5.1\_PS DR 7-2 Solar Capacity Fa\_F\_workpapers (confidential).xslm, specifically the sheet labeled as 'Future Solar'. ("Duke Response to PS DR 7-2")

<sup>7</sup> "Actual solar output is variable and dependent on natural irradiance (daylight) and cloud cover. Solar profiles modeled in the Resource Plan are based on a "typical meteorological year," ("TMY"), using 25 years of historical irradiance data from 22 sites across the Carolinas." Duke IRP, Appendix C: Quantitative Analysis, p. 25.

316 shows the hourly variation of solar generation that Duke assumes for July 1 – 5  
317 following the expected daily pattern of solar irradiance and variations in the  
318 amount of solar output day-to-day. Duke is able to handle the hourly variation of  
319 solar by dispatching other generation and storage down during solar generation  
320 hours and up during non-solar generation hours, as discussed in more detail  
321 below.

322



323

324 Source: Duke Confidential Response to PS DR 7-2.

325 [REDACTED] below shows the daily difference in total solar generation output.  
326 This figure counts the number of days per year that solar capacity factor is within  
327 the range shown on the bottom of the figure and differentiates days in each of the  
328 four seasons. For example, most days in the summer have solar output in the [REDACTED]  
329 [REDACTED] range with several higher in the [REDACTED] range and some lower in the [REDACTED]  
330 [REDACTED] range. In the winter though, the average output per day tends to be lower  
331 with the most in [REDACTED] range.



[Redacted text block]



340 Source: Duke Confidential Response to PS DR 7-2.

341 These figures demonstrate that the natural variation in solar generation by  
342 the hour, day, and season is accounted for in the IRP modeling.

343 **Q: CAN THE DUKE SYSTEM EFFICIENTLY RESPOND TO VARIATIONS**  
344 **IN SOLAR GENERATION?**

345 A: Yes. Duke responds to variations in solar generation in two important ways. First,  
346 in operating its system, Duke forecasts solar generation patterns for the next day  
347 based on weather forecasting and plant availability and plans its dispatch of  
348 system resources in conjunction with that projected output to serve load while  
349 also taking into account the availability and operating parameters of other  
350 resources. Second, Duke maintains operating reserves to respond to moment-to-  
351 moment changes in solar generation. This is similar to how Duke dispatches its  
352 generation resources to serve the daily cycles of its projected *load* and maintains  
353 operating reserves in case of generator outages as well as sudden changes in  
354 electricity demand.

355 **Q: HOW DOES DUKE DISPATCH ITS RESOURCES IN RESPONSE TO**  
356 **VARIATIONS IN SOLAR GENERATION?**


357 A: Yes. Duke has always had to plan for the dispatch of its resources to meet hourly  
358 changes in load and has installed “load-following” resources to do so, including  
359 natural gas CCs, storage, and certain types of hydroelectric generation. With  
360 increasing solar generation on its system, Duke now dispatches its resources to  
361 serve the amount of load that is not served by solar, often referred to as the “net  
362 load.” Duke dispatches its generation resources to serve load while accounting for  
363 the hourly solar generation as shown in Figure 5 below.<sup>8</sup> The figure shows

---

<sup>8</sup> Hourly generation by resource type is not available based on Duke’s IRP modeling due to data limitations.

364 hourly generation by resource type in the Duke Energy Progress East balancing  
 365 area for March 13 and 14, 2026 when solar is particularly high and load is  
 366 generally low. In fact, solar served about 50% of the hourly load from 1 – 3 pm  
 367 on March 14!

368 **FIGURE 5: DUKE ENERGY PROGRESS EAST GENERATION FOR MARCH 13-14,**  
 369 **2026**



370  
 371 Source: U.S. Energy Information Administration (“EIA”), Hourly Electric Grid  
 372 Monitor,  
 373 <https://www.eia.gov/electricity/gridmonitor/dashboard/custom/pending>,  
 374 accessed March 25, 2026.

375 In this high solar case, total generation is low in overnight hours (around  
 376 6,000 MW on March 13) and then starts to climb in the morning, resulting in  
 377 several resources increasing their output to serve the higher load. When solar  
 378 generation begins around 9 am, the other resources are dispatched down reducing  
 379 their total output by about 3,000 MW, primarily from reducing the output of  
 380 flexible gas generation. Resources then increase their output during the afternoon  
 381 hours to serve evening and overnight load. As Duke notes in its IRP report about  
 382 gas CCs, “[g]iven the flexibility of these resources to quickly ramp up and down

383 output, they are well equipped to operate dynamically within the fleet to integrate  
384 variable energy resources, like solar and wind, while meeting fluctuating load  
385 requirements.”<sup>9</sup> Gas CTs and storage are also well equipped to efficiently  
386 respond to the changes in load and renewable energy throughout the day.

387 Coal plants are generally less flexible, but the figure above shows coal  
388 output adjusting to changes in load and solar output. Due to low natural gas prices  
389 since around 2010, coal power plants have been less cost effective to run than Gas  
390 CCs and have had to operate more flexible over that timeframe. The costs of  
391 operating and maintaining coal plants while operating in this way is reflected in  
392 Duke’s assumptions for its variable and fixed operations and maintenance  
393 (“O&M”) cost assumptions. By 2032, Duke forecasts that the remaining 6.3 GW  
394 of coal plants will have a capacity factor of [REDACTED] when running on coal,  
395 such that their ramping costs, if any, are likely to be quite low.

396 **Q: YOU NOTED THAT DUKE WILL INCREASE ITS OPERATING**  
397 **RESERVES WITH INCREASING SOLAR CAPACITY. DOES DUKE**  
398 **INCLUDE THE NEED FOR ADDITIONAL OPERATING RESERVES IN**  
399 **ITS MODELING?**

400 **A:** Yes. In addition to the hourly variation in its solar generation profiles, Duke also  
401 accounts for the hourly uncertainty in solar generation by adjusting the amount of  
402 operating reserves that are on standby to generate in case of a sudden decrease in  
403 solar output. As noted in Appendix L, “the Plan accounts for these realities by  
404 updating the balancing and regulating reserve requirements used within the

---

<sup>9</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 31.

405 modeling process to capture the increased flexibility needs from variable  
406 renewable output.”<sup>10</sup>

407 **Q: DOES THE REQUIREMENT OF ADDITIONAL OPERATING**  
408 **RESERVES DUE TO MORE SOLAR CAPACITY INCREASE COSTS**  
409 **FOR DUKE?**

410 A: Yes, the increased operating reserves add costs to portfolios with greater solar  
411 generation because gas plants are operating at lower output and start up more  
412 frequently, which are accounted for in Duke’s IRP production cost modeling.

413 **Q: DOES DUKE CALCULATE THE MAGNITUDE OF THESE**  
414 **ADDITIONAL COSTS?**

415 A: Yes, Duke regularly calculates the incremental costs of the additional operating  
416 reserves due to increasing solar resources on the Duke system when setting the  
417 Solar Integration System Charge (“SISC”). As noted in the 2023 SISC report:

418 “unexpected changes in solar output can be cost effectively  
419 accommodated by increasing upward ancillary service targets  
420 within the existing conventional fleet. Increasing ancillary  
421 service targets forces the system to commit more generating  
422 resources which allows generators to dispatch at lower levels  
423 giving them more capability to ramp up. There is a cost to this  
424 increase in ancillary services because generators are operated  
425 less efficiently when they are dispatched at lower levels.  
426 Generators may also start more frequently, which also  
427 increases costs... This 2023 Study analyzes multiple solar  
428 penetration levels and quantifies the cost of utilizing the

---

<sup>10</sup> Duke IRP, Appendix L, Reliability and System Resilience, p. 10.

429                   |           existing fleet to reliably integrate the additional solar  
430                   |           generation.”<sup>11</sup>

431                   |           Duke calculates the SISC based on the incremental costs of the additional  
432                   |           operating reserves and the additional unit start costs divided by the megawatt-  
433                   |           hour (“MWh”) of solar generation. The most recent analysis of the SISC in 2023  
434                   |           calculated the SISC to be \$0.89/MWh to \$1.62/MWh across two tranches of solar  
435                   |           resources and the two service territories.<sup>12</sup> Based on recent solar costs, the SISC  
436                   |           adds only about 1% to the total costs of solar, which is immaterial to the amount  
437                   |           of solar generation selected by resource planning tools like EnCompass. As noted  
438                   |           by CCEBA in the 2025 Avoided Cost docket, E-100, Sub 211, the 2023 SISC  
439                   |           study may not account for the effects of greater BESS deployment in Duke’s  
440                   |           territory, which would further reduce the costs.

441                   |           Importantly, the 2023 SISC report finds that the volatility of generation  
442                   |           from installed solar resources decreases with increasing solar penetration, as  
443                   |           shown in Figure 6 below. Specifically, the figure shows that the amount of  
444                   |           deviations from a normalized profile decreases from nearly 4% at 1,000 MW of  
445                   |           installed solar capacity (blue dot labelled “DEC Historical”) to less than 2% at  
446                   |           7,000 MW (light blue dot labelled “Extrapolated 7,000 MW”).<sup>13</sup>


---

<sup>11</sup> Exhibit 2, 2023 SISC report, pp. 3-4.

<sup>12</sup> Exhibit 2, 2023 SISC report, Table ES-4, p. 8.

<sup>13</sup> Exhibit 2, 2023 SISC report, Figure 13, p. 32.

447

**FIGURE 6: SOLAR GENERATION VOLATILITY BY INSTALLED CAPACITY**

448

449

Source: Astrape Consulting, Duke Energy Carolinas and Duke Energy Progress

450

Solar Integration Service Charge (SISC) Study, November 1, 2023 (**Exhibit 2**),

451

p. 32.

452

This trend occurs because the addition of new solar resources diversifies

453

the location of the solar plants and the volatility in generation across solar

454

resources. The volatility of solar generation resources will continue to decrease as

455

additional solar is added well beyond 7,000 MW to nearly 12,000 MW in the

456

NTAP case based on the 2025 IRP.

457

**Q: DO OTHER CANDIDATE GENERATION RESOURCES HAVE UNIQUE**

458

**OPERATING PROFILES THAT DUKE MUST CONSIDER AND**

459

**ACCOUNT FOR IN ITS MODELING?**

460

**A:** Absolutely. Resource planning requires extensive analysis of the system needs as

461

well as the unique cost, capabilities, and limitations of each resource type. For

462

example, coal and nuclear generation facilities have long been key resources in

463

the Duke system but both resources are generally inflexible in their ability to

464 respond to changes in system conditions and so other resources need to be  
465 available to provide those services and account for the lack of flexibility of coal  
466 and nuclear power plants. Duke specifically notes that utilities are moving away  
467 from coal plants towards resources that are “more efficient, flexible, and cost-  
468 effective.”<sup>14</sup>

469 In addition, thermal generation resources including coal, gas and nuclear  
470 resources, experience unexpected outages that create challenges for operating the  
471 system. Duke evaluates the amount of additional resources it must add to the  
472 system “to maintain reliability through *unplanned outages* or higher than expected  
473 loads due to extreme weather events.”<sup>15</sup> The uncertainty created by thermal  
474 outages directly translates to higher costs for reliably serving load by increasing  
475 the amount of resources that have to be procured to meet planning reserve  
476 requirements.<sup>16</sup>

477 **Q: WHAT DOES DUKE ASSUME FOR THE CONTRIBUTIONS OF SOLAR**  
478 **TO MEETING ITS RESOURCE ADEQUACY NEEDS AND**  
479 **SPECIFICALLY THE PLANNING RESERVE REQUIREMENTS?**

480 A: Duke assumes that solar resources have a relatively low contribution to meeting  
481 the planning reserve requirements. Duke estimates the contribution of solar, wind  
482 and storage based on its ELCC, which it estimates through a separate study. The  
483 ELCC of solar is 10% or less.<sup>17</sup> The values are low because Duke’s modeling

---

<sup>14</sup> Duke IRP, Appendix F: Coal, p. 1.

<sup>15</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 69.

<sup>16</sup> See, e.g., Winter Storm Elliot, as discussed in **Exhibit 6**.


<sup>17</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 25.

484 identifies winter mornings as the primary driver of reliability events throughout  
485 the year before solar resources start generating or are generating very little.

486 **Q: DOES THAT MEAN SOLAR HAS NO VALUE AT ALL TO**  
487 **MAINTAINING A RELIABLE SYSTEM?**

488 A: No, the way Duke calculates ELCC does not mean that the solar resources on the  
489 Duke system are not valuable to maintaining a reliable system. On the contrary,  
490 some of the highest load throughout the year occurs in the summer during  
491 daylight hours when solar is generating. Solar output during this period is critical  
492 to maintaining a reliable power system. Increased solar reduces the likelihood of  
493 reliability events during the periods when it is producing. And without solar  
494 resources, the frequency of reliability events during peak load periods would  
495 otherwise be higher. The more solar enters the system, the more it reduces the  
496 “net load” during the middle of the day and the chance of a reliability event  
497 during those times, shifting reliability events to other non-solar hours. Figure 7  
498 below demonstrate that in the summer of 2025 solar played a key role in meeting  
499 peak demand and significantly lowering net peak demand. Solar will continue to  
500 do so in the future with additional resources. While the incremental reliability  
501 need will likely get pushed to later in the evening when solar does not produce,  
502 the advent of battery storage at scale should enable stored solar energy to assist in  
503 meeting this later peak.

504

**FIGURE 7: SUMMER AND WINTER 2025 PEAK DAY LOAD AND NET LOAD**

505

506

Source: Duke IRP, Appendix L: Reliability & Operational Resilience, p. 10.

507

**Q: ARE THERE ANY ASSUMPTIONS IN DUKE’S MODELING THAT RESULT IN UNDERESTIMATING THE FUTURE CAPACITY OF SOLAR?**

508

509

510

**A:** Yes, there are two assumptions in particular that tend to underestimate the value of solar in Duke’s modeling: the full value of storage is not captured and they do not account for opportunities to export excess solar.

511

512

513

**Q: HOW DOES THE DUKE IRP MODELING NOT FULLY ACCOUNT FOR THE VALUE OF STORAGE?**

514

515

**A:** Resource planning modeling performed by Duke and other resource planners across the country relies primarily on normalized inputs for hourly demand,

516

517

hourly renewable energy generation, daily natural gas prices, transmission

518

outages, and fossil resource outages. These normalized assumptions

519

underestimate the volatility that occurs in the real-world power system. As Duke

520

notes in its IRP documents, the EnCompass capacity expansion model normalizes

521

system conditions by using “a simplified, average representation of hourly system

522 demand to screen for the optimal resource portfolio for a given set of input  
523 assumptions.”<sup>18</sup> Battery storage resources provide significant value to the power  
524 system by taking advantage of the expected and unexpected volatility of the  
525 market, absorbing the output of low-cost generation during certain hours and  
526 injecting power back into the system during high-cost hours, as well as providing  
527 operating reserves and regulation services. By not accounting for the actual  
528 market conditions of its system, Duke will underestimate costs of serving load  
529 during especially high cost hours. By missing that value, models like EnCompass  
530 will significantly underestimate the amount of cost-effective storage capacity.

531           This is a common issue across resource planning models because fully  
532 accounting for real-world market conditions over a multi-decade period requires  
533 new approaches and assumptions. But there are ways to better capture storage  
534 value in resource planning models. Two approaches that my colleagues and I at  
535 The Brattle Group have implemented to account for this common shortcoming are  
536 to: (1) calculate the missing value for battery storage in a separate analysis based  
537 on historical volatility in market conditions and then add that value into the  
538 capacity expansion model as an offset to annual fixed battery storage costs; and,  
539 (2) develop more representative assumptions for the load profiles, renewable  
540 energy generation, and natural gas prices that account for non-normalized  
541 conditions and include them in the capacity expansion model. I have recently  
542 supported an electric utility in making similar refinements to their modeling  
543 capability to account for the full value of storage following the first option noted

---

<sup>18</sup> Duke IRP, Chapter 2: Methodology, p. 22.

544 above. I highly recommend that Duke pursue improvements in its modeling  
545 capability to better value storage resources in its resource planning models in  
546 future IRP planning studies.

547 **Q: DOES UNDERESTIMATING THE VALUE OF STORAGE AFFECT**  
548 **SOLAR RESOURCES?**

549 A: Yes. More storage resources on the Duke system will tend to increase the value of  
550 solar by providing low-cost supply for charging the storage resources. This  
551 relationship between storage capacity and solar resource additions can be clearly  
552 seen in the Duke sensitivity cases. Specifically, Duke ran a sensitivity case with  
553 lower cost storage, which can also represent a case in which additional storage  
554 value is included in the model. The low storage cost case results in an additional  
555 2,800 MW of storage *and* 1,875 MW of additional solar on the system compared  
556 to the preliminary base case, displacing about 1,800 MW of gas resources.<sup>19</sup> This  
557 demonstrates that by not fully capturing the value of storage, Duke’s modeling  
558 skews the results away from solar and storage.

559 **Q: HOW DOES DUKE MODEL ITS INTERACTIONS WITH**  
560 **NEIGHBORING UTILITIES AND MARKETS?**

561 A: Duke models its system as an island without opportunities to sell excess power to  
562 its neighboring system or purchase imports for cost-effectively serving load on a  
563 non-firm basis. Duke specifically notes that it does not include the ability to  
564 transact with its neighboring system through the existing bilateral trading market  
565 in the Southeast known as SEEM, explaining that “because these potential, 15-

---

<sup>19</sup> Duke IRP, Appendix C: Quantitative Analysis, Table C-30, p. 56.

566 minute economic energy purchases and sales are as-available, non-firm, and  
567 completely dependent on neighboring utilities' load and resource availability, as  
568 well as the availability of non-firm transmission to deliver the energy, the  
569 Companies do not include the potential economic benefit of SEEM in their  
570 resource planning modeling.”<sup>20</sup> Similarly, Duke does not include transactions  
571 with the PJM electricity market.

572 This modeling approach does not reflect the real world. Duke transacts  
573 with neighboring systems and can offer its generation or purchase generation via  
574 SEEM. However, SEEM transaction volumes have been relatively small to date.<sup>21</sup>  
575 The use of the existing non-firm transfer capability with neighboring systems for  
576 cost-effective transactions – through bilateral transactions or via SEEM – is less  
577 than would occur if Duke were to participate in an energy imbalance market or a  
578 day-ahead energy market.

579 **Q: WHY DOES MODELING THE DUKE SYSTEM WITHOUT ACCESS TO**  
580 **IMPORTS OR EXPORTS RESULT IN LESS SOLAR CAPACITY**  
581 **ADDITIONS?**

582 A: The “islanded” utility assumption has an impact on solar resource additions in the  
583 Duke modeling because, without accounting for and including transactions with  
584 neighboring systems, solar resources will be curtailed more frequently to avoid  
585 periods of overgeneration. As Duke notes in Appendix L, “On the lowest-load  
586 days (such as mild and sunny spring days), solar energy and other non-solar

---

<sup>20</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 11.

<sup>21</sup> <https://southeastenergymarket.com/wp-content/uploads/SEEM-Audit-Report-Annual-2024-F.pdf>.

587 generation may need to be curtailed to maintain system reliability at the LROL  
588 [Lowest Reasonable Operating Level] if other management options are not  
589 available.”<sup>22</sup>

590 If instead Duke included in its modeling the ability to *export* energy from  
591 solar to neighboring systems, Duke would increase off-system sales revenue,  
592 which would reduce the net costs to Duke’s customers and increase the value of  
593 the solar resources compared to simply curtailing its output. In the near-term,  
594 solar curtailment is most likely to occur in the spring and fall when load is lower  
595 and output of solar is still fairly high (as shown above), but with increasing solar  
596 penetration it can also occur in other months.

597 **Q: ARE THERE MODELING APPROACHES THAT DUKE CAN**  
598 **IMPLEMENT TO BETTER CAPTURE THE VALUE OF ADDITIONAL**  
599 **NON-FIRM TRANSACTIONS WITH ITS NEIGHBORING SYSTEMS?**

600 **A:** Yes. Including interactions with neighboring systems is a common modeling  
601 practice in the industry. To better capture the value of off-system sales, utilities  
602 often follow one of two approaches. Some resource planners include in their  
603 models a larger geographic footprint than their own system that includes  
604 neighboring systems and allows for transactions between systems on a non-firm  
605 basis up to the limits of the transmission system. Alternatively, utilities will allow  
606 the model to schedule imports and exports up to transmission limits based on an  
607 hourly estimate of the marginal costs of resources in neighboring systems. When  
608 Duke’s marginal costs are lower than its neighboring systems, such as during

---

<sup>22</sup> Duke IRP, Appendix L, p. 10.

609 excess generation periods, the model will choose to export to their neighbors and  
610 earn revenues from doing so. Either of these approaches would increase the value  
611 of solar during periods of excess generation, reduce curtailments, and increase the  
612 volume of cost-effective solar selected by the capacity expansion model.

613 **Q: WILL DUKE BE ABLE TO SCHEDULE IMPORT AND EXPORT**  
614 **TRANSACTIONS WITH ITS NEIGHBORING SYSTEMS AS**  
615 **EFFICIENTLY AS A MODEL WOULD ALLOW?**

616 A: SEEM is a step in that direction by enabling participating utilities to efficiently  
617 schedule transactions on a 15-minute basis between neighboring systems and  
618 across the region. With solar growing across the Southeast, scheduling  
619 transactions to efficiently utilize resources during periods of excess generation  
620 will become a more common driver for transactions across the SEEM region. The  
621 FERC filing for SEEM specifically noted this benefit, stating that SEEM will  
622 “allow for better integration of diverse generation resources, including rapidly  
623 growing renewables, and is expected to reduce renewable curtailments.”<sup>23</sup>

624 However, SEEM’s ability to produce those benefits using its current  
625 market structure is likely to be limited. The Annual Audit Report on the Southeast  
626 Energy Exchange Market by the SEEM Independent Market Auditor Potomac  
627 Economics notes that total trading volume in 2024 across the full SEEM footprint  
628 (not just DEC and DEP) was just 1,055 GWh.<sup>24</sup> However, the report highlights

---

<sup>23</sup> [Affidavit of Aaron Melda and Lonnie Bellar](#) (Overview Affidavit), Attachment B to the Transmittal Letter, P 26. (Exhibit 3).

<sup>24</sup> <https://southeastenergymarket.com/wp-content/uploads/SEEM-Audit-Report-Annual-2024-F.pdf>, p. 2. (Exhibit 4).

629 that transactions are increasing, indicating “increased interest and confidence in  
630 the market.”<sup>25</sup>

631 Based on these findings, SEEM transactions currently are limited but may  
632 be able to enable an increasing volume of efficient market transactions in the real-  
633 time operation of the Duke system by the mid-2030s. Assuming in the IRP  
634 modeling that these transactions are not available for efficiently operating their  
635 market all the way through 2050 is not reasonable and reduces the value of solar  
636 on Duke’s system and overlooks potential cost savings for ratepayers.

637 **Q: ARE THERE OTHER MARKET DESIGNS COULD MORE**  
638 **EFFICIENTLY SCHEDULE TRANSACTIONS WITH NEIGHBORING**  
639 **SYSTEMS, LOWER SYSTEM COSTS, AND INCREASE THE VALUE OF**  
640 **SOLAR IN DUKE’S SYSTEM?**


641 A: Yes. Alternative approaches to scheduling transactions and utilizing available  
642 non-firm transmission are available, and they have proven better able to cost-  
643 effectively utilize excess generation from solar. For example, reducing  
644 curtailments of (and monetizing the benefits of) renewable energy is a chief  
645 benefit of the Western Energy Imbalance Market (“WEIM”). WEIM has been in  
646 operation across most of the Western U.S. for over 12 years and includes regions  
647 *without* a regional transmission operator (“RTO”). A map of the WEIM service  
648 territory is shown below.

649

---

<sup>25</sup> *Id.*, p. 6.

650

**FIGURE 8: WESTERN ENERGY IMBALANCE MARKET PARTICIPANTS**

651

652

653

Source: <https://www.westernenergymarkets.com/western-energy-imbalance-market-weim>

654

655

656

657

658

659

660

Compared to the limited transactions enabled by SEEM, WEIM more efficiently utilizes available non-firm transmission capacity in the real-time energy market compared and reduced renewable energy curtailments by 258 GWh in 2025.<sup>26</sup> Greater utilization of low-cost generation that would otherwise have been curtailed is one of the reasons that WEIM provided \$416 million of benefits in the fourth quarter of 2025 to its participants, with \$408 million of the benefits going to non-RTO participants.<sup>27</sup> In fact, since its inception, WEIM has provided


<sup>26</sup> <https://www.westernenergymarkets.com/documents/iso-western-energy-imbalance-market-benefits-report-q4-2025.pdf>, p. 15. (Exhibit 5).

<sup>27</sup> *Id.*, p. 3.

661 \$8.2 billion in benefits, again with the majority of those benefits to non-RTO  
 662 participants (\$7.1 billion).<sup>28</sup>

663 The Western Energy Imbalance Service operated by the Southeast Power  
 664 Pool (“SPP”) provides similar services to non-RTO service territories in several  
 665 states, including Wyoming, Colorado, and New Mexico, as shown in Figure 9.

666 **FIGURE 9: WESTERN ENERGY IMBALANCE SERVICE PARTICIPANTS**



667

668 Source: <https://spp.org/western-services/weis/>

669 **Q: WOULD PARTICIPATING IN AN ENERGY IMBALANCE MARKET**  
 670 **REQUIRE DUKE TO JOIN AN RTO?**

671 A: No. The Western Energy Imbalance Market and the Western Energy Imbalance  
 672 Service both operate in non-RTO portions of the western U.S. and do not require  
 673 participants to join an RTO. The participants in these energy imbalance market  
 674 include vertically integrated utilities similar to Duke, including PacifiCorp, NV  
 675 Energy, Arizona Public Service, and Xcel Energy Colorado.

<sup>28</sup> <https://www.westernenergymarkets.com/western-energy-imbalance-market-weim/benefits>

676 **Q: DO OTHER MARKETS IN THE U.S. INCLUDE MORE SOLAR THAN**  
677 **THE DUKE SYSTEM?**

678 A: Yes. Solar generation is currently [REDACTED] of the total generation in the Duke system  
679 and is projected to reach [REDACTED] of its generation mix in 2035 in the NTAP scenario.  
680 Two markets have much more solar today. The 2025 generation mix of the  
681 ERCOT market in Texas included 14% of total generation from solar and an  
682 additional 23% from wind resources, amounting to 37% of generation from  
683 renewable energy resources.<sup>29</sup> The most recent generation data from California is  
684 from 2024 and shows that 23% of its generation came from solar resources and an  
685 additional 7% from wind, totaling up to 31% from wind and solar energy.<sup>30</sup>

686 In the past month, ERCOT reached nearly 80% of its load being met by a  
687 combination of solar and wind. From 9 am to 6 pm on March 14, total renewable  
688 energy generation served at least 70% of its load, as shown in Figure 10 below.

---


<sup>29</sup> ERCOT, [Interval Generation by Fuel Report](#), March 9, 2026.

<sup>30</sup> California Energy Commission, [In-State Electric Generation by Fuel Type \(GWh\)](#), accessed March 24, 2026.

689

690

FIGURE 10: ERCOT GENERATION MIX ON MARCH 14, 2026



691

692 Source: GridStatus, accessed March 28, 2026,


693 <https://www.gridstatus.io/live/ercot?date=2026-03-14>

694

695 In California, the renewable energy generation in CAISO on March 22,  
 696 2026 served over 90% of its demand for most of the daylight hours and exceeded  
 697 its total demand for an hour, resulting in about 5 GW of exports into the  
 698 surrounding power system. The CAISO generation mix on that day is shown in  
 Figure 11 below.

699

FIGURE 11: CAISO GENERATION MIX ON MARCH 22, 2026



700

701 Source: GridStatus, accessed March 28, 2026,

702 <https://www.gridstatus.io/live/caiso?date=2026-03-22>.

703 **Q: HAS THE ADDITION OF SOLAR MADE THOSE SYSTEM LESS**  
 704 **RELIABLE?**

705 A: No. Even at much higher penetrations of solar and wind, these markets remain  
 706 highly reliable. Market rules have been adjusted to account for the variability in  
 707 output of renewable energy generation by increasing operating reserves and in  
 708 CAISO a flexible reserve. However, the incremental costs of these reserves are  
 709 relatively small and efficiently met by existing resources, including flexible gas  
 710 resources and increasing penetration of battery storage.

711 **Q: ARE THERE ANY DIFFERENCES IN MARKET DESIGN THAT**  
 712 **IMPACT HOW WELL THESE OTHER MARKETS CAN INTEGRATE**  
 713 **HIGHER SOLAR CAPACITY?**

714 A: Yes, both ERCOT and the California market, as noted above, include regional  
 715 real-time and day-ahead energy markets that allow for efficient use of resources,  
 716 including solar.

717 **Q: CAN YOU PLEASE SUMMARIZE YOUR RECOMMENDATIONS TO**  
718 **THE COMMISSION BASED ON YOUR REVIEW OF THE IRP**  
719 **MODELING?**

720 **A:** I have three recommendations. First, Duke should improve its modeling to better  
721 capture the value of battery storage. Second, Duke should improve its  
722 representation of transactions with its neighboring systems in its model to better  
723 account for the availability and value of non-firm transactions on the most cost-  
724 effective resource portfolio. Third, the Commission should require Duke to study  
725 the effectiveness of SEEM for enabling efficient transactions with neighboring  
726 systems, including the current limitations to the market framework and  
727 improvements that can be made to SEEM to increase its effectiveness, and  
728 compare the effectiveness of SEEM to a regional Southeast energy imbalance  
729 market similar to the markets currently in place in the non-RTO portions of the  
730 western U.S.

731 **II. REVIEW OF DUKE IRP MODELING RESULTS**

732 **Q: DID DUKE FIND ADDITIONAL SOLAR RESOURCES TO BE COST-**  
733 **EFFECTIVE IN ITS MODELING AND IN ITS NEAR-TERM ACTION**  
734 **PLAN (NTAP)?**


735 **A:** Yes, Duke identified a need for ongoing solar capacity additions to its system  
736 through 2040. In its Preliminary Base case, Duke expects to add about 8,175 MW  
737 of new solar resources by 2040.<sup>31</sup> Across an additional 30 scenarios, Duke

---

<sup>31</sup> Duke IRP, Appendix C: Quantitative Analysis, p. 51.

738 identified a wide of range of outcomes for future solar additions by 2040, ranging  
 739 from no additional solar in the Low Load scenario to nearly 14 GW in the High  
 740 Load scenario.<sup>32</sup> As shown in Figure 12, most of the scenarios add more solar  
 741 than the Base Preliminary case (orange bar). Reflecting the range of additional  
 742 solar capacity Duke identified across the scenarios, Duke included 10.3 GW of  
 743 solar by 2040 in the Near-Term Action Plan scenario (“NTAP”) (yellow bar).

744 **FIGURE 12: 2040 SOLAR CAPACITY BY SCENARIO**



745

746 Source: Duke IRP, Appendix C: Quantitative Analysis, pp. 51-62.

747 **Q: WHICH SCENARIOS RESULT IN THE HIGHEST SOLAR ADDITIONS?**

748 A: In addition to the High Load scenario, Duke added at least 12 GW of new solar  
 749 resources in four additional scenarios: No Wind Availability, High Nuclear Costs,  
 750 High Gas Prices, and Low Solar Costs.

<sup>32</sup> Duke IRP, Appendix C: Quantitative Analysis, pp. 51-62

751 **Q: DO OTHER SCENARIOS RESULT IN SOLAR CAPACITY ADDITIONS**  
752 **SIMILAR TO THE NTAP SCENARIO?**

753 A: Yes, there are ten additional scenarios where Duke finds a need for approximately  
754 10 GW of solar resources, including the Utility Combination (DEC-DEP merger)  
755 scenario.

756 **Q: IS IT REASONABLE FOR DUKE TO INCLUDE MORE SOLAR IN ITS**  
757 **NTAP THAN IDENTIFIED IN ITS PRELIMINARY BASE PORTFOLIO?**

758 A: Yes, absolutely. The results of the scenarios demonstrate across a wide range of  
759 future system conditions that more solar capacity is cost-effective to the future  
760 Duke system than identified in the specific assumptions in the Preliminary Base  
761 scenario. Specifically, the High Load, High Nuclear Cost, and High Gas Price  
762 cases demonstrate that solar resources are needed today to be prepared for future  
763 system conditions that can materialize.

764 **Q: WHY DOES SOLAR PROVIDE A COST-EFFECTIVE RESOURCE TO**  
765 **THE DUKE SYSTEM IN THE CAROLINAS?**

766 A: As noted earlier in my testimony, solar resources generate during high load  
767 periods during the middle of the day, displacing the need for operating resources  
768 that have significant operating costs primarily through the consumption of fuel,  
769 including natural gas and coal. During these periods, Duke will need to dispatch  
770 less efficient, higher cost resources to meet that demand. More solar resources  
771 reduces the need to incur those costs. In addition, solar provides the additional  
772 generation needed to charge the increasing capacity of storage resources on the  
773 system. The storage resources are able to shift dispatch of energy from solar hours

774 to evening and morning hours when load is high but the sun is not shining. This is  
775 especially the case when natural gas prices are higher, increasing the costs of  
776 running all natural gas-fueled power plants, particularly the least efficient plants.

777 Solar also produces electricity without generating any carbon dioxide  
778 emissions. While the interim target for reducing emissions was removed recently,  
779 Duke still must meet the long-term decarbonization objectives by 2050, as set by  
780 legislation in North Carolina, and many of Duke's largest customers have their  
781 own carbon dioxide-reduction requirements and seek cleaner forms of generation.  
782 Meeting those long-term objectives requires making steady progress to avoid the  
783 risks and costs of attempting a sudden, very large change in Duke's resource mix  
784 in the late 2040s.

785 In addition, solar resources are currently in development across the Duke  
786 service territory and provide a known resource that is relatively low-risk to  
787 develop and is not dependent on additional fuel infrastructure for adding new  
788 capacity and serving future load. While transmission improvements are needed to  
789 connect solar to load centers, Duke is actively pursuing transmission projects that  
790 support the future generation and load needs of the system, providing multiple  
791 system benefits such as reduced production costs, increased reliability, and access  
792 to new cost-effective generation resources.

793 **Q: WHAT DOES DUKE IDENTIFY AS THE PRIMARY VALUE DRIVERS**  
794 **OF SOLAR ADDITIONS IN ITS SYSTEM?**

795 A: In their testimony, Duke's Solar and Energy Storage Panel summarizes four  
796 drivers of the value of solar, including (1) hedging against fuel price volatility, (2)

797 hedging against delayed additions from other resources, (3) ensuring energy  
798 adequacy throughout the year, and (4) reducing system production costs.<sup>33</sup>  
799 Similarly, the IRP and Near-Term Actions Panel notes that “[a]s a fuel-free  
800 resource, additional solar in these sensitivities provides a commodity price risk  
801 hedge by reducing natural gas consumption on the system” and “several portfolios  
802 increase near term solar deployments to offset risk in other planning  
803 considerations, such as high natural gas price or not relying on wind resources  
804 over the long term.”<sup>34</sup>

805 **Q: WHAT RESOURCES DOES SOLAR DISPLACE WHEN IT IS ADDED**  
806 **TO THE DUKE SYSTEM?**

807 A: Based on Duke’s modeling, the addition of more solar on the Duke system in the  
808 mid-2030s primarily reduces [REDACTED]  
809 [REDACTED]. Later in the 2030s, the  
810 solar additions start to displace output from [REDACTED]  
811 as well. To identify the impact of additional solar resources on the generation  
812 mix, I specifically compared the annual generation by resource type from Duke’s  
813 production cost modeling of the Preliminary Base scenario and the NTAP  
814 scenario.<sup>35</sup> The NTAP scenario includes about [REDACTED] more solar in 2035. [REDACTED]  
815 [REDACTED] below shows from 2034 to 2036 that the additional solar adds [REDACTED]  
816 [REDACTED]

---

<sup>33</sup> Direct Testimony of Maura Farver, Gray Tompson, and Ben Smith, p. 18.

<sup>34</sup> Direct Testimony of Glen Snyder, et al., p. 57 and 61.

<sup>35</sup> I analyzed the EnCompass production cost model results for the Preliminary Base and NTAP scenarios provided by Duke in the files “2.20\_2025 IRP - Base Portfolio - PC.xlsx” and “2.101\_2025 IRP - NTAP - PC.xlsx”, specifically the sheets labeled ‘Resource Annual’. (“Duke Preliminary Base and NTAP PC Results”)

820

821

822 Source: Duke Preliminary Base and NTAP PC Results

823 **Q: DO THESE RESULTS SUPPORT THE VALUE OF SOLAR YOU NOTED**  
824 **ABOVE AND DUKE WITNESSES NOTED IN THEIR TESTIMONY?**

825 A: Yes, these results support the view that solar provides value to the Duke system  
826 by avoiding high-cost generation while also reducing emissions from both coal  
827 and gas generation.

828 **Q: PLEASE EXPLAIN THE VALUE OF REDUCING GAS BURN.**

829 A: While gas generators are a key part of the portfolio of resources to cost-  
830 effectively serve future load, they also expose Duke customers to greater cost  
831 risks from fluctuations in the commodity prices of natural gas. The monthly  
832 average prices of natural gas at the Henry Hub trading hub since 2020 have



833 fluctuated from just under \$2/MMBtu to nearly \$9/MMBtu, as shown in Figure  
 834 14 below.<sup>36</sup> The price of natural gas has significant impacts on the cost of running  
 835 natural gas CC and CT resources to serve electricity customers. The graph shows  
 836 that there were periods of relatively low gas prices in the \$2-4/MMBtu range, but  
 837 there were also sustained periods of higher prices in 2022 (averaging  
 838 \$6.42/MMBtu throughout the year) and a recent spike in prices in January 2026 to  
 839 \$7.70/MMBtu (reaching over \$25/MMBtu for two days).

840 **FIGURE 14: HISTORICAL HENRY HUB NATURAL GAS PRICES (\$/MMBTU)**



841

842 Source: EIA, [Henry Hub Natural Gas Spot Price](#), accessed March 24, 2026

843 Duke accounted for uncertain natural gas prices by creating three  
 844 projections of future natural gas prices and modeling scenarios based on each  
 845 projection. The natural gas prices in each case remain below \$5/MMBtu in all  
 846 cases through 2030.<sup>37</sup> Gas prices increase in the 2030s in the base case to about  
 847 \$6/MMBtu in 2040, stay below \$5/MMBtu in the low case, and climb to  
 848 \$13/MMBtu in 2040 in the high case. Importantly, Duke's modeling does not

<sup>36</sup> EIA, [Henry Hub Natural Gas Spot Price](#), accessed March 24, 2026.

<sup>37</sup> Duke IRP, Appendix C: Quantitative Analysis, Figure C-7, p. 40.

849 consider in any of those cases the spikes in prices shown in the figure above  
850 throughout 2022 or in January 2026.

851 **Q: IS DUKE’S EXPOSURE TO NATURAL GAS COMMODITY PRICE RISK**  
852 **INCREASING IN THE FUTURE?**

853 A: Yes, by quite a lot. Duke is proposing in its NTAP to build about 10 GW of new  
854 gas CC and Gas CT plants by 2035. Duke’s modeling of the NTAP scenario  
855 shows that its reliance on gas generation will [REDACTED] by 2035, climbing from  
856 [REDACTED] GWh in 2025 to [REDACTED] GWh in 2035, as shown in the figure below. This  
857 will result in generation from natural gas resources increasing from [REDACTED] of the  
858 total generation in 2025 to [REDACTED] from 2032 to 2035, an increase of [REDACTED]. By  
859 comparison, the projected solar additions in the NTAP will reach [REDACTED] of total  
860 generation in 2035.



862  
863 Source: Duke Preliminary Base and NTAP PC Results.

864 **Q: WILL SOLAR REDUCE EXPOSURE TO GAS COMMODITY PRICE**  
865 **RISK?**

866 A: Yes, increasing the amount of generation from other resources onto the system,  
867 especially resources that require no fuel to generate, provides a defensive hedge  
868 against commodity price spikes and sustained periods of elevated prices. Solar  
869 resources fill that role well.

870 **Q: DOES DUKE’S MODELING DEMONSTRATE THE VALUE OF SOLAR**  
871 **RESOURCES WITH HIGHER NATURAL GAS PRICES?**

872 A: Yes, in the High Gas scenario Duke’s IRP modeling builds an additional 4 GW of  
873 solar compared to the Preliminary Base scenario and an additional 2 GW  
874 compared to the NTAP scenario, as shown in Figure 12 above.<sup>38</sup>

875 **Q: ARE THERE ANY OTHER RISKS ASSOCIATED WITH RELIANCE ON**  
876 **NATURAL GAS?**

877 A: Yes. Bringing 10 GW of new natural gas capacity on to the system will require  
878 significant new natural gas supply infrastructure. The NTAP includes building  
879 new gas pipelines and liquified natural gas (“LNG”) storage capacity.<sup>39</sup> The first  
880 three new Gas CCs (Person County CC1 and CC2 and Anderson County CC3)  
881 will rely on existing firm transportation service and additional firm transportation  
882 provided by two projects that are currently in development: the Transco Southeast  
883 Supply Enhancement and Mountain Valley Pipeline Southgate. The additional 3  
884 CCs identified to be needed will rely on either enhanced liquified natural gas  
885 (“ELNG”) or additional firm transportation from the Gulf Coast.

---

<sup>38</sup> Duke IRP, Appendix C: Quantitative Analysis, Table C-29, p. 55.

<sup>39</sup> Duke IRP, Chapter 2: Table 2-5, p. 18.

886                   There are significant execution risks associated with building this  
887 infrastructure, especially natural gas pipelines. For example, the Mountain Valley  
888 Pipeline that provides Duke access to natural gas production from the Marcellus  
889 shale region was delayed by six years from 2018 to 2024. Earlier, the Atlantic  
890 Coast Pipeline developed by Duke and Dominion to serve new natural gas plants  
891 was cancelled. Similar delays in building natural gas pipelines to serve Duke’s  
892 new gas resources will limit Duke’s ability to serve its growing load.

893                   Duke acknowledges these risks, identifying insufficient fuel supply due to  
894 litigation of pipeline infrastructure as a primary execution risk for its buildout of  
895 its natural gas-fired generation resources: “[t]he increase in natural gas generating  
896 capacity, however, has led to adequate natural gas supply being the largest risk.”<sup>40</sup>  
897 Duke further notes that “the Transco SSE and Southgate projects are both  
898 required for the Companies to be able to successfully execute their planned least-  
899 cost fleet transformation while supporting load growth.”<sup>41</sup>

900                   This amount of natural gas also increases the reliability risk of correlated  
901 outages of natural gas plants during winter storms. During Winter Storm Elliot,  
902 Duke had over 5,000 MW of generation capacity that was unable to operate due  
903 to planned and forced outages.<sup>42</sup> The outages included several natural gas plants  
904 that were unable to generate due to frozen instrumentation and natural gas

---

<sup>40</sup> Duke IRP, Appendix I: Natural Gas & Low-Carbon Fuels, p. 22.

<sup>41</sup> Duke IRP, Appendix I: Natural Gas & Low-Carbon Fuels, p. 22.

<sup>42</sup> GDS Associates, Inc., Inspection and Examination Report of Duke Energy Carolinas, LLC and Duke Energy Progress, LLC: December 2022 Winter Storm Outages and Blackouts, Prepared for the South Carolina Office of Regulatory Staff, Docket No. ND-2023-1-E, August 25, 2023. (**Exhibit 6**).

905 deliverability issues due to insufficient pressure in the natural gas pipeline  
906 system.<sup>43</sup>

907 **Q: WILL ADDING SOLAR AT THE LEVEL PROPOSED IN THE NTAP**  
908 **REDUCE RISKS ASSOCIATED WITH INCREASING RELIANCE ON**  
909 **GAS RESOURCES?**

910 A: Yes, by adding more solar generation to the system through the annual  
911 procurement processes, Duke will add new non-gas generation resources to the  
912 system ahead of the need and be ready to serve larger loads on its system even if  
913 there are delays to permitting and construction of new natural gas infrastructure.  
914 To provide the capacity to maintain reliability during both peak periods and  
915 during winter storms that impact the availability of gas to the Duke system, Duke  
916 will also need to continue to add more battery storage resources along with the  
917 solar additions.

918 **Q: WHY DOES THE HIGH LOAD CASE RESULT IN THE MOST SOLAR**  
919 **ADDITIONS?**

920 A: As noted above, the High Load case results in the most solar additions, reaching  
921 14 GW by 2040.<sup>44</sup> This outcome is not surprising because with higher load  
922 growth Duke will need more generation resources to serve that load. But what  
923 stands out about the High Load scenario in particular is that even with an  
924 additional 1.5 GW of peak demand and 20 TWh of load compared to the  
925 Preliminary Base scenario Duke finds *no* increase in gas CC or gas CT capacity,

---

<sup>43</sup> *Id.*

<sup>44</sup> Duke IRP, Appendix C: Quantitative Analysis, Table C-27, p. 53.

926 coal plant capacity, or nuclear capacity. Zero! Instead, in the High Load case,  
927 Duke adds another 5.6 GW of solar, 1.8 GW of battery storage, and 300 MW of  
928 onshore wind.

929 Duke adds no new gas resources in the High Load scenario because it  
930 projected that it can only add six new combined cycles plants by 2035 and it  
931 builds up to that limit under the base case load growth. Duke limits new gas CC  
932 builds based on its experience developing large gas plants, site availability, fuel  
933 supply infrastructure limits, and permitting challenges.<sup>45</sup>

934 Therefore, when additional load materializes, Duke will need to rely on  
935 other resources. Solar and storage are the primary resources available to serve the  
936 additional load. If North Carolina wishes to attract all of the demand in the High  
937 Load case, Duke will need to add more energy to its system to serve that load  
938 through increased adoption of solar and storage.

939 **Q: WHY ARE OTHER RESOURCES NOT SELECTED IN THE HIGH**  
940 **LOAD CASE?**

941 **A:** Duke has a limited set of resource options in the near-term for meeting a  
942 significantly higher projection of load growth both in terms of total annual energy  
943 demand (in gigawatt-hours) and peak demand requirements (in terms of  
944 gigawatts). I will touch on each of the resources that is being considered by Duke  
945 to be added through 2035:

---

<sup>45</sup> See Duke IRP, Chapter 2, Table 2-5 (“Beginning with CC4, additional Enhanced Firm Transportation (“EFT”) natural gas supply delivered from the Gulf Coast.” And, “Cumulative limit of three additional CCs with EFT supply.”)

- 946 ▶ Natural Gas: As noted above, Duke has set limits on new Gas CC builds by  
947 2035 based on its experience developing large gas plants, site availability, fuel  
948 supply infrastructure limits, and permitting challenges. All of the available  
949 new Gas CC capacity is selected in nearly every scenario Duke modeled,  
950 including the Preliminary Base scenario, such that Duke is unable to build  
951 additional Gas CCs to serve the load in the High Load scenario.
- 952 ▶ Coal: Duke explains that there are four key factors that make it costly and  
953 risky to continue to operate existing coal generation fleet: (1) risks to coal  
954 supplier viability in a market with declining domestic demand; (2) coal supply  
955 chain risks and transportation constraints that limit flexibility to respond to  
956 rapid changes in demand; (3) coal fleet operational constraints; and (4)  
957 uncertainty surrounding environmental requirements impacting the coal  
958 generation fleet.<sup>46</sup> For these reasons, Duke is continuing to pursue 6 GW of  
959 coal plant retirements by 2035, while primarily running the remaining plants  
960 on natural gas.
- 961 ▶ Onshore and Offshore Wind: Duke is limited in the amount it can develop  
962 within its territory with no new onshore or offshore wind in its base plan or  
963 NTAP due to the lack of resources in development.<sup>47</sup>
- 964 ▶ Nuclear: Duke reviewed the available nuclear technologies and their  
965 development timelines and determined they will not be available until 2037.<sup>48</sup>

---

<sup>46</sup> Duke IRP, Appendix F: Coal.

<sup>47</sup> Duke IRP, Appendix C: Quantitative Analysis, pp. 32-35.

<sup>48</sup> Duke IRP, Appendix C: Quantitative Analysis, pp. 35-36.

966 **Q: WHAT ARE YOUR TAKEAWAYS BASED ON THESE LIMITATIONS**  
967 **IN THE RESOURCES THAT DUKE CAN ACCESS?**

968 A: In addition to solar being a hedge against higher natural gas commodity prices (as  
969 noted by Duke witnesses), solar is also the resource that Duke can continue to add  
970 in parallel to new Gas CCs to reduce the risk that it will have insufficient energy  
971 generation available to serve future load and support economic development in  
972 the State. Delays in natural gas infrastructure development and other challenges to  
973 development both cap how much Duke can rely on new gas CCs builds and also  
974 highlight the risks of relying on such a large deployment of new resources. In  
975 order to get ahead of those limits, Duke should be pursuing as much solar  
976 capacity as it can currently interconnect to reduce its risks of having insufficient  
977 resources to serve the higher end load forecasts.

978 **Q: WILL SOLAR RESOURCES BE UTILIZED IF THE PROJECTED**  
979 **DEMAND DOES NOT MATERIALIZE?**

980 A: Yes, because solar costs primarily are upfront capital costs, once the resources are  
981 built, they will produce as projected (or close to it, given the variations noted  
982 above) with effectively zero marginal production costs. Because solar resources  
983 do not incur additional costs to generate, they will produce whether demand is  
984 high or low.<sup>49</sup> By comparison, the output of fossil fuel-fired resources, especially  
985 higher cost resources like new CTs and existing coal plants, will vary depending  
986 on year-to-year variations in total electricity demand and the total load growth.

---

<sup>49</sup> Duke contractually pays solar resources for their output on a per-MWh basis at a pre-set rate and can only curtail so much of its output. In this way, the contractual cost of solar is a sunk cost and does not factor into real-time generation dispatch decisions.

987 For that reason, the risk of solar resources not supporting future energy demands  
988 is near-zero.

989 In addition, if Duke determines in the next several years that the High  
990 Load scenario is unlikely to materialize, Duke can pivot its procurements in future  
991 years and reduce solar capacity targets for future procurements if updated load  
992 forecasts demonstrate that the expected future load level is unlikely to reach the  
993 High Load scenario. This “no regrets” approach will also provide a more stable  
994 market for the development of multi-year solar projects – increasing execution  
995 certainty and reducing costs – while avoiding the inefficiency of having to  
996 procure very large amounts of solar in a short period in the out years to make up  
997 for lower procurements in earlier ones.

998 **Q: WHAT IS YOUR RECOMMENDATION FOR THE COMMISSION**  
999 **BASED ON YOUR REVIEW OF THE RESULTS OF DUKE’S IRP**  
1000 **MODELING?**

1001 A: To best prepare to serve the High Load Case as well as hedging against the cost  
1002 factors discussed above, I recommend procurement of more solar in the 2026 to  
1003 2028 procurement processes then set forth in the NTAP.<sup>50</sup> I view the NTAP as the  
1004 minimum necessary procurement and believe an additional 230 MW to 430 MW  
1005 per year up to the 1,200 MW build limit would be prudent. If Duke determines at  
1006 a later date that the High Load scenario is unlikely to materialize, Duke can then  
1007 reassess its future procurement levels of solar.

1008

---

<sup>50</sup> Duke IRP, Chapter 4, Table 4-2, p. 10.

1009 **III. REVIEW OF DUKE'S TRANSMISSION PLANNING PROCESS**

1010 **Q: WHAT APPROACHES IS DUKE TAKING TO COST-EFFECTIVELY**  
1011 **INTERCONNECT NEW RESOURCES, INCLUDING SOLAR, INTO ITS**  
1012 **TRANSMISSION SYSTEM?**

1013 A: Duke has made several significant improvements to its transmission planning and  
1014 interconnection processes over the past several years, many at the urging of the  
1015 Commission. The improvements include implementation of cluster studies in the  
1016 interconnection process (including a separate cluster for its solar solicitations), the  
1017 identification and construction of RZEP projects, and the completion of the first  
1018 MVST planning process through the CTPC. Building on these improvements, Duke  
1019 should continue to implement these processes effectively and make additional  
1020 changes to its processes to improve its ability to incorporate cost-effective  
1021 resources into its system and reduce ratepayer costs.

1022 **Q: WHAT ARE THE BENEFITS OF THE RZEP PROJECTS?**

1023 A: The RZEP projects build out the transmission system in regions of the Duke system  
1024 with significant low-cost solar resources and as a result will reduce the costs and  
1025 time required for interconnecting those resources. The projects were identified as  
1026 needed through several rounds of interconnection studies and verified to be  
1027 necessary for interconnecting future solar resources in the 2023 Public Policy  
1028 Study. However, due to the nature of the interconnection study process, the RZEP  
1029 projects had not yet been selected for construction as network upgrades since their  
1030 costs would have been borne by the first few generators seeking interconnection --

1031 even though those upgrades would provide transmission capacity that would serve  
1032 a much larger set of resources that benefit the Duke system.

1033           Due to the system-wide benefits they provide for cost-effectively meeting  
1034 the future resource needs of the system and reducing the risk of outages, Duke  
1035 added the RZEP upgrades to the CTPC transmission plan. By doing so, the  
1036 upgrades are built on a coordinated basis in anticipation of need, reducing the  
1037 costs of building future network upgrades and reducing the time required for  
1038 future economic resources to be studied and interconnected. The RZEP projects  
1039 also have reliability benefits by replacing existing facilities with higher capacity  
1040 ones, which will reduce risk of loss of load. As Duke notes in Appendix K, “[t]he  
1041 RZEP projects eliminate barriers to interconnecting resources in both South  
1042 Carolina and North Carolina and have stand-alone value based on the merits of  
1043 replacing aging equipment and the associated reduction in the probability of  
1044 customer service interruptions.”<sup>51</sup>

1045           This approach of identifying backbone-type upgrades identified frequently  
1046 in the interconnection study process and pulling them into the transmission  
1047 planning process is a good one. It debottlenecks future interconnection studies,  
1048 avoids the same upgrades continually limiting new resource additions, reduces  
1049 costs, and reduces the time needed for constructing network upgrades. But, it only  
1050 considers the next set of resources seeking interconnection and does not account  
1051 for system-wide needs over a longer timeframe. The addition of the MVST  
1052 process helps fill that gap.

---

<sup>51</sup> Duke IRP, Appendix K: Transmission, p. 10.

1053 **Q: WHAT IS THE MVST PLANNING PROCESS?**

1054 A: The MVST planning process is a newly-implemented proactive transmission  
1055 planning study completed by the CTPC for identifying cost-effective transmission  
1056 upgrades. The MVST process starts by identifying several future scenarios to  
1057 model, including the future load and generation mix over a ten-year timeframe. The  
1058 CTPC then identifies the future transmission needs in each scenario, prioritizes  
1059 those needs into clusters, develops solutions to cost-effectively meet those needs,  
1060 and analyzes the benefits and costs of several solutions and eventually the full  
1061 portfolio of MVST solutions. This approach differs from existing reliability studies  
1062 that look only at the reliability-driven needs of the system (i.e., resolving  
1063 transmission element overloads), do not incorporate all of the future generation  
1064 additions planned to serve future load, and do not include a cost-benefit analysis of  
1065 the candidate solutions to evaluate whether new transmission enable delivery of  
1066 lower cost generation to customers.

1067 The primary advantages of the MVST compared to the prior transmission  
1068 planning processes include:

- 1069 ▶ A scenario-based approach to analyzing system needs that accounts for key  
1070 uncertainties in the Duke power system and evaluates common upgrades  
1071 required across multiple futures;
- 1072 ▶ Coordinated planning of both load and generation that leverages the recent  
1073 results of Duke's resource planning studies;

- 1074 ▶ Multi-value benefits analysis of transmission identifies which upgrades  
1075 provide the most bang-for-the-buck and demonstrates that transmission  
1076 investments can reduce total costs for serving load;
- 1077 ▶ Increased transparency about planning assumptions, needs, and solutions and  
1078 opportunities for stakeholders to provide input on the study approach and  
1079 results; and,
- 1080 ▶ Development of new tools for evaluating the impacts of transmission  
1081 investments and the needs of the future Duke system.

1082 The MVST process draws from significant experience with multi-value,  
1083 scenario-based transmission planning at the regional level across the country.

1084 What makes the MVST process unique is that it is occurring within the local  
1085 transmission planning process for the Duke service territory in North Carolina and  
1086 South Carolina and that it is being completed in a region without a centralized  
1087 energy market.

1088 **Q: WHICH FUTURE SCENARIOS DID THE MVST STUDY?**

1089 A: The CTPC requested input from stakeholders on which futures to study and  
1090 received input from several stakeholders that resulted in the first MVST studying  
1091 three scenarios based on the P1 Fall Supplemental Portfolio and P3 Fall  
1092 Supplemental Portfolio generation resource portfolios from the 2023 Carolinas  
1093 Resource Plan approved by the Commission.<sup>52</sup> The scenarios include a single  
1094 outlook for load growth and two different resource mixes: the P1 Fall Supplemental  
1095 Portfolio included a higher level of solar (21 GW) and offshore wind (2.4 GW) and

---

**Exhibit 7.**

1096 the P3 Fall Supplemental Portfolio included less (13 GW of solar and 1.7 GW of  
1097 offshore wind). The third scenario shifted the location of the new solar resources  
1098 between DEC and DEP. Utilizing these scenarios the MVST study analyzed two  
1099 key uncertainties about the future system coming out of the 2023 resource planning  
1100 process: the amount and location of future solar resources. While the future  
1101 locations of new resources are unknown, the CTPC utilized the generator  
1102 interconnection queue as an indication of future resource development and  
1103 requested input from solar developers to ensure that the locations aligned with their  
1104 expectations.

1105 In addition to the scenarios, the CTPC also studied multiple sensitivities  
1106 for each scenario to test whether needs persisted with incremental changes in load  
1107 and additional offshore wind.

1108 **Q: DID THE MVST STUDY IDENTIFY A NEED FOR TRANSMISSION**  
1109 **UPGRADES?**


1110 A: Yes, the CTPC implemented the future scenarios into its local reliability planning  
1111 models to identify future reliability-driven needs. The CTPC identified significant  
1112 reliability violations on both the DEC and DEP systems, as shown in the maps  
1113 below. The CTPC prioritized the reliability needs based on a number of factors to  
1114 identify those that occur in the most scenarios and sensitivities and provide  
1115 capacity for interconnecting the most new resources. At the request of stakeholders,  
1116 the CTPC then identified specific clusters of violations to evaluate during the  
1117 solutions development step of the MVST study.

1118

FIGURE 16: MVST RELIABILITY-DRIVEN NEEDS



1119



1120

1121 Source: Duke IRP, Appendix K: Transmission System Planning & Grid Transformation,  
1122 p. 12.

1123 **Q: DID THE MVST STUDY IDENTIFY NEEDS BASED ON UNECONOMIC**  
1124 **DISPATCH AND OTHER DRIVERS IN ADDITION TO RELIABILITY?**

1125 A: No, the first MVST solely focused on reliability-driven needs utilizing powerflow  
1126 models and did not evaluate constraints on the system that result in higher dispatch  
1127 costs for serving load throughout the year, which are commonly referred to as  
1128 “economic” drivers of transmission needs. Reliability-driven needs focus on  
1129 studying challenging periods for operating the system and serving load, such as  
1130 summer peak and winter peak conditions, and which constraints arise during  
1131 contingency events that coincide with peak demand, such as transmission outages  
1132 and generation outages. These studies are necessary to ensure reliable service to the  
1133 Duke system.

1134 In addition to maintaining system reliability, transmission upgrades can  
1135 also reduce the costs of serving load by accessing lower cost generation resources,  
1136 both in terms of reducing the costs of building new resources and the cost of  
1137 operating generation resources, which is the basis for the “multi-value” focus of  
1138 the MVST process. Economic drivers are most often identified utilizing  
1139 production cost models that evaluate system needs throughout the year on an  
1140 hourly basis and identify when transmission constraints result in an uneconomic  
1141 dispatch. An uneconomic dispatch arises when Duke must operate a higher-cost  
1142 resource instead of a lower-cost resource because the lower-cost resource is  
1143 limited by a transmission element. Uneconomic dispatch results in higher  
1144 generation costs to serving load than otherwise would occur if more transfer  
1145 capability were available. Compared to reliability models, production cost models  
1146 look at a wider range of system load and generation dispatch conditions that occur  
1147 throughout the year and evaluate the cost impacts of transmission constraints.


1148                    In the case of the MVST, the CTPC did not yet have an operational  
1149                    production cost model of its system with sufficient granularity to perform the  
1150                    economic needs assessment of the transmission system at the beginning of its  
1151                    study. Several stakeholders raised the need for the development of a production  
1152                    cost model that includes a detailed representation of Duke’s transmission lines,  
1153                    substations, generation resources, and load, which is often referred to as a “nodal”  
1154                    model, for performing the needs assessment as well as the benefits analysis. Duke  
1155                    regularly performs production cost modeling within the IRP, but at a zonal level  
1156                    rather than a nodal level. Zonal production cost modeling aggregates the demand  
1157                    and generation resources in portions of its system into zones without detailed  
1158                    representation of the transmission system. This level of detail is sufficient for  
1159                    resource planning and evaluation of generation needs, but is insufficient for  
1160                    evaluating the future needs of the transmission system. By the end of the MVST  
1161                    study, the CTPC had developed such a nodal production cost model and utilized it  
1162                    for the benefits analysis.

1163                    I recommend that in future iterations of the MVST the CTPC perform both  
1164                    a reliability-driven needs assessment as well as an economic-driven needs  
1165                    assessment for identifying transmission constraints on its system that results in  
1166                    uneconomic dispatch and higher costs for serving load. This additional needs  
1167                    assessment will help the CTPC and its stakeholders identify transmission  
1168                    solutions that maximize the benefits of transmission investments for Duke’s  
1169                    customers.

1170 **Q: HAS THE MVST STUDY IDENTIFIED COST-EFFECTIVE**  
 1171 **TRANSMISSION UPGRADES?**

1172 A: Yes, after studying multiple solutions to the identified reliability-driven needs, the  
 1173 CTPC released its benefits analysis for a portfolio of transmission upgrades. The  
 1174 analysis demonstrates that there are significant benefits to the portfolio of upgrades  
 1175 being proposed across all three scenarios and sensitivities related to natural gas  
 1176 prices and load growth. **FIGURE 17** below shows the benefits of the MVST  
 1177 portfolio as stacked bars with each section showing the source of the benefits,  
 1178 including congestion and fuel savings (due to reductions in uneconomic dispatch),  
 1179 avoided customer outages (from replacing aging transmission lines), avoided  
 1180 transmission investments (due to reducing loading on constraints that triggered an  
 1181 upgrade in the CTPC Base Reliability plan), and generation capacity savings from  
 1182 reduced losses (reducing total capacity needs to serve peak loads).

1183 **FIGURE 17: MVST PORTFOLIO BENEFITS ANALYSIS (\$ MILLION)**



1184  
 1185 Source: CTPC, MVST 2024 - Multi-Value Analysis - Portfolio - Draft - 2026 03 10,  
 1186 March 20, 2026. [https://carolinastpc.org/media/reference/2026/03/20/MVST\\_2024\\_-](https://carolinastpc.org/media/reference/2026/03/20/MVST_2024_-_Multi-Value_Analysis_-_Portfolio_-_Draft_-_2026_03_10.xlsx)  
 1187 [\\_Multi-Value\\_Analysis\\_-\\_Portfolio\\_-\\_Draft\\_-\\_2026\\_03\\_10.xlsx](https://carolinastpc.org/media/reference/2026/03/20/MVST_2024_-_Multi-Value_Analysis_-_Portfolio_-_Draft_-_2026_03_10.xlsx)

1188                   The benefits analysis demonstrates that the MVST portfolio cost savings  
1189                   and reliability benefits of \$0.9 billion to \$2.3 billion greatly exceed the costs of  
1190                   \$0.3 billion. The benefits are highest in Scenario 3, in which more solar is located  
1191                   in DEP, and in the high load sensitivities when the system will be the most  
1192                   stressed. The large congestion and fuel savings in the high load case in particular  
1193                   demonstrate how transmission investments provide a hedge against the higher  
1194                   costs of serving load when demand is particularly high in a given year or if the  
1195                   system load grows faster than expected (as it is now doing).

1196       **Q:   WHAT ARE YOUR PRIMARY TAKEAWAYS FROM THE FIRST MVST**  
1197       **STUDY?**

1198    A:   I have several takeaways from the MVST process but want to note that the  
1199           complete benefits analysis of the proposed MVST portfolio was recently released  
1200           and requires additional review through the CTPC stakeholder process. At this stage,  
1201           my takeaways on the outcomes of the MVST include:

- 1202           ▶   The MVST successfully developed a set of future scenarios for the CTPC to  
1203               study that is integrated with the Duke resource planning study, providing an  
1204               important link between resource planning and transmission planning that did  
1205               not previously exist for the Duke service territory;
- 1206           ▶   The needs assessment in particular demonstrated the large scale of  
1207               transmission upgrades required for serving future load and interconnecting  
1208               new generation resources and required the CTPC transmission planners to  
1209               prioritize the highest value needs on the system;

- 1210 ▶ The MVST required the CTPC to look differently at their system by  
1211 prioritizing areas of needs and addressing the highest value projects first, as  
1212 well as developing new tools for identifying transmission needs and assessing  
1213 alternative solutions;
- 1214 ▶ The MVST study demonstrates the multi-value nature of transmission in the  
1215 Duke system and provided transparency about the costs and cost savings of  
1216 incremental transmission investments beyond the standard reliability-driven  
1217 studies;
- 1218 ▶ The CTPC provided significant information throughout the process in terms of  
1219 its modeling approach, results, solutions development, and benefits analysis  
1220 for stakeholders to consider and provide feedback, and the CTPC has been  
1221 timely and comprehensive in providing responses; and,
- 1222 ▶ The MVST successfully identified several upgrades that provide significant  
1223 benefits to the system and would not have been built otherwise, reducing costs  
1224 to ratepayers and supporting future generation additions and load growth.

1225 **Q: DO YOU HAVE ANY RECOMMENDATIONS FOR THE NEXT MVST**  
1226 **STUDY?**

1227 A: Yes, while I am still reviewing the final results from the MVST study recently  
1228 posted by the CTPC, at this time I would recommend the following for the next  
1229 MVST study:

- 1230 ▶ Given the uncertainty in load identified in the current resource planning study,  
1231 the next MVST scenarios should include at least two projections of future load  
1232 growth;

- 1233 ▶ The CTPC should summarize constraints in the base case production cost  
1234 model that result in uneconomic dispatch and the costs of the binding  
1235 constraints during the needs assessment phase, similar to the results shared for  
1236 the reliability models, and provide a summary to stakeholders for their review;
- 1237 ▶ The CTPC should validate its production cost model by replicating the load,  
1238 generation resource mix, renewable energy generation profiles, and natural  
1239 gas prices of a recent historical year and comparing key outputs from the  
1240 model, including generation mix, renewable curtailments, and total production  
1241 costs, against their actual system in order to identify how well the model  
1242 reflects the real-world system; and,
- 1243 ▶ The CTPC should present in more detail its analysis of each of the benefits so  
1244 that stakeholders can understand the impacts of each proposed solution to the  
1245 system and the drivers of benefits.

1246 **Q: HOW DOES PROACTIVE TRANSMISSION PLANNING IMPROVE THE**  
1247 **GENERATION INTERCONNECTION PROCESS?**

1248 A: Proactive transmission planning will improve the generation interconnection  
1249 process in three ways. First, generation developers will have better information  
1250 earlier in the development cycle about where there is headroom on the system that  
1251 will result in lower interconnection costs and less schedule risks. Second, the  
1252 interconnection studies will be less complex and require less time as  
1253 interconnection studies will identify fewer incremental upgrades and the upgrades  
1254 will primarily be upgrades at or near the point of interconnection. Third, fewer

1255 incremental network upgrades will mitigate the schedule risks to developers of  
1256 interconnecting new resources and reduce outage coordination challenges for Duke.

1257 **Q: SHOULD DUKE CONTINUE TO IDENTIFY AREAS OF NEED FOR**  
1258 **DEVELOPING PROACTIVE PROJECTS BASED ON THE**  
1259 **INTERCONNECTION STUDIES?**

1260 A: Yes, interconnection queues and interconnection study results should continue to be  
1261 an important source of information for the types, amount, and location of resources  
1262 that are currently in development and the transmission system upgrades necessary  
1263 to integrate those resources. Ideally, those needs and the associated upgrades would  
1264 be considered in the MVST process and either validated, like they have been in the  
1265 2023 public policy study and the first MVST study, or replaced by larger and more  
1266 cost-effective upgrades that can support interconnection of new resources and  
1267 provide other benefits to the Duke system. To do so, Duke must allow recently  
1268 identified upgrades in the interconnection studies as well as reliability studies to be  
1269 replaced by holistic upgrades identified through the MVST study process.

1270 **Q: DOES DUKE PARTICIPATE IN REGIONAL TRANSMISSION**  
1271 **PLANNING?**

1272 A: Yes, through SERTP.

1273 **Q: DOES SERTP'S PLANNING APPROACH IDENTIFY COST-EFFECTIVE**  
1274 **REGIONAL UPGRADES?**

1275 A: No, the current SERTP process is quite limited and has not identified a single  
1276 regional transmission project since its inception in 2007. The Southeast region that  
1277 SERTP covers is going through a period of rising transmission costs, significant

1278 load growth and generation resource additions, and increasing severity and  
1279 frequency of winter storms, all of which can be aided by improved regional  
1280 transmission. However, the SERTP process is not currently designed to identify  
1281 regional transmission solutions that will increase the transfer capability between  
1282 utility service territories and provide significant benefits to the region. In 2025 I  
1283 completed a study that summarized the current SERTP transmission planning  
1284 process, identified shortcomings of its process, and recommended changes to its  
1285 regional planning process.<sup>53</sup>

1286 **Q: WHAT ARE THE PRIMARY ISSUES WITH THE SERTP REGIONAL**  
1287 **TRANSMISSION PLANNING PROCESS THAT YOU IDENTIFIED IN**  
1288 **YOUR STUDY?**

1289 **A:** The regional planning process that SERTP completes is an annual “bottom-up”  
1290 process that primarily combines the updated load and generation assumptions and  
1291 local transmission upgrades from each of its sponsor utilities and confirms that the  
1292 system meets its reliability requirements. The regional study is limited in scope as  
1293 it only considers a single future scenario based on the base assumptions included in  
1294 each of the sponsor utility’s local planning process and does not utilize the multiple  
1295 scenarios developed in the resource planning studies, such as the current 2025  
1296 Carolinas Resource Plan study. Similarly, the regional planning study only includes  
1297 a subset (about 12%) of the new generation resources identified in the most recent  
1298 resource planning studies. Specifically, as of 2025, the SERTP regional planning  
1299 studies only included 10 GW of new resources by 2035 across its region, even

---

<sup>53</sup> **Exhibit 8.**

1300 though the resource planning studies across the region identified a need for 80 GW  
1301 of new resources in the same timeframe. As noted above, this approach reflects the  
1302 reliability-only approach previously employed by the CTPC in its reliability study  
1303 and does not reflect the coordinated generation and transmission planning the  
1304 CTPC completed through the MVST study. Finally, the SERTP process lacks  
1305 transparency as limited information is provided on the costs of transmission in the  
1306 regional plan, reliability violations identified in its planning studies, and alternative  
1307 approaches studied to meet regional needs. This approach will not identify and  
1308 approve the most cost-effective transmission infrastructure to reliably serve future  
1309 load across the Southeast.

1310 **Q: DID YOU EVALUATE WHETHER REGIONAL TRANSMISSION**  
1311 **UPGRADES WOULD PROVIDE BENEFITS TO THE CUSTOMERS**  
1312 **ACROSS THE SOUTHEAST?**

1313 **A:** Yes, based on an economic request to study 10 GW of transfers from MISO to  
1314 Southern Company, SERTP identified three 500 kV upgrades that cost about \$5  
1315 billion and increase transfer capability between the Duke, Southern Company, and  
1316 TVA service territories. To demonstrate the value of Southeast regional  
1317 transmission, my colleagues and I performed a high-level analysis of the benefits  
1318 and costs of these three 500 kV upgrades. While SERTP evaluates regional projects  
1319 only based on their ability to avoid local upgrades, our analysis evaluated the  
1320 potential cost savings and other benefits of the regional projects utilizing recent  
1321 historical market data and based on an expanded set of benefits, including

1322 production cost savings, load diversity benefits, and resilience benefits during  
1323 extreme weather conditions.

1324 **Q: WHAT DID YOUR ANALYSIS OF REGIONAL UPGRADES IN SERTP**  
1325 **FIND?**


1326 A: Using an expanded set of benefits, we estimated that the three 500 kV projects  
1327 would provide about \$8 billion of cost savings and other benefits to the region,  
1328 resulting in \$3 billion of net benefits for customers across the Southeast, including  
1329 Duke's service territory, over the life of the assets. The benefits included:  
1330 production cost savings of \$2.0 billion to \$3.6 billion; load diversity-related cost  
1331 savings of \$0.9 billion to \$6.0 billion; and resilience benefits of \$0.7 billion to \$2.3  
1332 billion. By contrast, SERTP's narrow view of benefits identified **no** cost savings  
1333 from the addition of three major 500 kV lines to the Southeast system. This  
1334 analysis demonstrates that regional transmission upgrades can reduce system costs  
1335 when a broader scope of cost savings and other benefits are analyzed.

1336 **Q: WHAT WERE THE RECOMMENDATIONS OF YOUR STUDY FOR**  
1337 **IMPROVING SERTP'S REGIONAL TRANSMISSION PLANNING**  
1338 **PROCESS?**

1339 A: I recommended that the SERTP leverage the significant experience across the  
1340 industry over the past 20 years with improved transmission planning approaches to  
1341 improve its process and reduce long-term system costs and risks. I specifically  
1342 noted that SERTP should learn from the experience gained from the Midcontinent  
1343 Independent System Operator's Long-Range Transmission Planning Process and  
1344 the CTPC's MVST local transmission planning process within SERTP's footprint. I

1345 recommended nine specific changes to the SERTP process, as shown in **FIGURE 18**  
 1346 below.

1347 **FIGURE 18: RECOMMENDATIONS FOR IMPROVING SERTP REGIONAL PLANNING**



1348

1349 Source: Hagerty, et al., Modernizing Southeast Grid Investments: How Enhanced  
 1350 Regional Transmission Planning Supports a Growing Economy, April 2, 2025, p. 5.  
 1351 (Exhibit 8).

1352 Compliance with FERC Order No. 1920 provides SERTP and its sponsor  
 1353 utilities, including Duke, an opportunity to enhance its regional transmission  
 1354 planning process. Order No. 1920 requires SERTP to implement a proactive,  
 1355 long-term, multi-value regional planning process, similar to MVST at the regional  
 1356 level, presenting a pivotal opportunity for the Southeast to align its regional  
 1357 transmission planning with industry best practices developed over the past 10–20  
 1358 years. The Southeast should embrace this opportunity to modernize its regional  
 1359 transmission planning to build a stronger, more efficient grid that supports  
 1360 economic growth, energy affordability, and long-term resilience.

1361 **Q: WHAT IS THE ROLE OF THE COMMISSION IN IMPROVING**  
 1362 **TRANSMISSION PLANNING AND INTERCONNECTION PROCESS TO**  
 1363 **ACHIEVE LEAST-COST OUTCOMES FOR RATEPAYERS?**

1364 A: The Commission should continue to review Duke's transmission planning and  
1365 interconnection processes to identify opportunities for improving the processes and  
1366 reducing costs to ratepayers while maintaining or improving system reliability. The  
1367 Commission's recommendations in the 2022 Carbon Plan proceeding played an  
1368 important role in Duke recently reforming these processes and the Commission  
1369 should continue to track those reforms to ensure they are implemented effectively.  
1370 In particular for the large-scale of upgrades required to transform the transmission  
1371 network, the Commission should ensure that Duke provides a clear and transparent  
1372 justification for the scenarios and contingencies tested in interconnection and  
1373 transmission planning studies and the alternative solutions considered for  
1374 maintaining reliability at least cost to ratepayers.

1375 In addition, the Commission should actively participate in the  
1376 development of the SERTP Order No. 1920 compliance filing and urge Duke to  
1377 leverage its experience with the MVST process to support a proactive, multi-  
1378 value, scenario-based planning process at SERTP that exceeds the requirements  
1379 of Order No. 1920 and supports cost-effective regional transmission upgrades  
1380 across the Southeast.

1381 **IV. SUPPORT FOR CEBA'S PROPOSED CLEAN CUSTOMER TARIFF**

1382 **Q: ARE YOU FAMILIAR WITH THE DIRECT TESTIMONY SUBMITTED**  
1383 **BY PRIYA BARUA AND STEVEN LEVITAS ON BEHALF OF CEBA IN**  
1384 **THIS PROCEEDING?**

1385 A: Yes. I have spoken with Mr. Levitas and reviewed a draft of the Direct Testimony  
1386 of Ms. Barua and Mr. Levitas in its entirety. Their testimony proposes a new clean

1387 customer tariff structured around six core elements, and explains in detail why  
1388 Duke's existing Green Source Advantage Choice program has failed to meet the  
1389 needs of large customers with clean energy goals.

1390 **Q: DO YOU AGREE WITH CEBA'S CONCLUSION THAT THE EXISTING**  
1391 **GSA CHOICE PROGRAM IS NOT MEETING THE NEEDS OF LARGE**  
1392 **C&I CUSTOMERS?**

1393 A: Yes, I do, in my experience large customers generally are actively seeking  
1394 opportunities to procure clean energy. However, as I understand it, the GSA Choice  
1395 program does not offer the one feature that most large customers with serious clean  
1396 energy commitments require: additionality.

1397 **Q: CAN YOU EXPLAIN WHAT ADDITIONALITY MEANS AND WHY IT**  
1398 **MATTERS TO A SUCCESSFUL CLEAN CUSTOMER TARIFF?**

1399 A: Additionality, as used in CEBA's testimony and as I understand it, means that a  
1400 customer's financial commitment to a clean energy resource is the reason that  
1401 resource was built, and that it would not have been constructed absent the  
1402 customer's participation. This is not an abstract or aspirational concept. It is a  
1403 practical requirement imposed by corporate sustainability frameworks, investor  
1404 disclosure standards, science-based emissions reduction targets, and third-party  
1405 verification protocols. When a customer subscribes to a resource that would have  
1406 been built regardless of their participation, they receive no attributable incremental  
1407 environmental benefit. They may be simply paying more for electricity without  
1408 advancing their clean energy goals in any meaningful or verifiable way. Under  
1409 those circumstances, a rational customer could decline to participate, and that is

1410 what appears to have happened with the GSA Standard option and the Resource  
1411 Acceleration Option.

1412 **Q: DO YOU AGREE WITH CEBA'S CHARACTERIZATION OF WHY THE**  
1413 **GSA STANDARD OPTION AND THE RESOURCE ACCELERATION**  
1414 **OPTION HAVE ATTRACTED NO SUBSCRIBERS?**

1415 A: Yes. CEBA's testimony explains why each option falls short and I agree with their  
1416 characterization of the problems. Under the GSA Standard option, resources that a  
1417 customer brings to Duke are counted toward Duke's own procurement targets to  
1418 meet Duke's system needs, meaning the customer's participation causes no net  
1419 increase in clean energy on the system. The customer bears the cost and effort of  
1420 selecting a project but may produce no attributable incremental clean energy  
1421 generation or incremental reduction of greenhouse gas emissions. Under the  
1422 Resource Acceleration Option, the available resources for procurement are limited  
1423 to projects that participated and lost in the prior Duke RFP, and additionality is  
1424 limited to only a few years - the period by which the customer's participation  
1425 accelerates a resource that Duke was already planning to eventually procure.  
1426 Customers seeking to count resources toward long-term clean energy goals cannot  
1427 credibly do so on the basis of a few years of accelerated deployment. Neither  
1428 option meets the basic cost-benefit test that a large customer would likely apply  
1429 before committing capital to a voluntary clean energy program.

1430 **Q: PLEASE SUMMARIZE YOUR UNDERSTANDING OF THE SIX**  
1431 **ELEMENTS OF CEBA'S PROPOSED CLEAN CUSTOMER TARIFF.**

1432 A: CEBA proposes a tariff built around the following six elements.

1433 First, participating customers would be permitted to bring new dedicated  
1434 carbon-free resources to Duke's system, including not only traditional utility-scale  
1435 generation but also energy efficiency programs, aggregated behind-the-meter  
1436 resources, and demand-side management measures, and would receive the  
1437 environmental attributes associated with those resources.

1438 Second, customers would be free to work directly with developers of their  
1439 choosing to identify the preferred size, technology type, and location of their  
1440 resource, without being limited to projects that were unsuccessful in Duke's  
1441 competitive solicitations.

1442 Third, participating customers would pay the full cost of their dedicated  
1443 resource plus a reasonable administrative fee, ensuring that non-participating  
1444 customers bear no additional costs.

1445 Fourth, participating customers would receive bill credits reflecting the  
1446 full avoided energy, avoided capacity, and system value that their resource  
1447 provides to Duke's system.

1448 Fifth, and most critically, the resources customers bring to the system  
1449 would be incremental to the resources Duke would otherwise procure pursuant to  
1450 its Commission-approved Near-Term Action Plan, establishing genuine  
1451 additionality.

1452 Sixth, multiple customers would be permitted to pool their demand and  
1453 jointly subscribe to a single clean energy resource, extending the program's  
1454 benefits to customers whose load alone may not justify a dedicated utility-scale  
1455 project.

1456 **Q: DO YOU SUPPORT EACH OF THESE SIX ELEMENTS?**

1457 A: Yes. Each element addresses a specific limitation of the existing GSA Choice  
1458 program or a specific need expressed by large customers seeking to meet their  
1459 clean energy commitments. Taken together, the six elements form a coherent and  
1460 well-designed program that to my understanding is responsive to the actual needs  
1461 of the large customers it is designed to serve.

1462 **Q: IS THE FIFTH ELEMENT, ADDITIONALITY TO DUKE'S NEAR-TERM**  
1463 **ACTION PLAN, THE MOST IMPORTANT FEATURE OF CEBA'S**  
1464 **PROPOSAL?**

1465 A: Based on my understanding of the goals of the members of CEBA, yes, it is the  
1466 most important feature in terms of distinguishing CEBA's proposal from the  
1467 existing GSA Choice program and making the proposed tariff attractive to large  
1468 customers. Without it, the program would offer little meaningful improvement over  
1469 what already exists and would likely attract similarly low participation. However, I  
1470 would emphasize that the other elements are also essential. A program that offers  
1471 genuine additionality but does not allow customers to select their preferred  
1472 resources, or that does not fully compensate customers for the value their resources  
1473 provide to the system, would still fail to attract the level of participation needed to  
1474 achieve the program's broader goals.

1475 **Q: DO YOU SUPPORT THE INCLUSION OF DEMAND-SIDE RESOURCES**  
1476 **SUCH AS ENERGY EFFICIENCY, BEHIND-THE-METER CLEAN**  
1477 **ENERGY, AND DSM MEASURES IN THE PROPOSED TARIFF?**

1478 A: Yes. The inclusion of demand-side resources is an innovative and pragmatic feature  
1479 of CEBA's proposal. These measures can typically be deployed more quickly than  
1480 utility-scale generation resources, reducing near-term pressure on Duke's system  
1481 while longer lead-time resources are developed. They also provide direct benefits to  
1482 the households and small businesses that participate in efficiency and behind-the-  
1483 meter programs funded by large customers. Given the pace of load growth Duke is  
1484 projecting and the potential for supply chain and interconnection constraints to  
1485 delay new generation, the Commission should welcome any mechanism that allows  
1486 large customers to deploy their capital quickly and effectively toward measurable  
1487 system benefits and increase the economic well-being of the State.

1488 **Q: DOES CEBA'S PROPOSAL ADEQUATELY PROTECT NON-**  
1489 **PARTICIPATING CUSTOMERS FROM COST SHIFTS?**

1490 A: Yes, if done properly. CEBA has been explicit that the proposed tariff must be  
1491 revenue neutral for non-participants. Participating customers would pay the full  
1492 cost of their dedicated resources and a reasonable administrative fee. Non-  
1493 participating customers would pay for the output of the new dedicated carbon-free  
1494 resources based on the avoided cost of those resources, meaning they pay no more  
1495 than they would have paid for the equivalent energy and capacity in the absence of  
1496 the program. This is a sound and fair approach that the Commission should find  
1497 consistent with its obligation to ensure just and reasonable rates for all customers.

1498 **Q: CEBA'S TESTIMONY NOTES THAT NORTH CAROLINA SENATE**  
1499 **BILL 266 REMOVED THE 2030 INTERIM CARBON EMISSIONS**  
1500 **REDUCTION TARGET. DOES THAT CHANGE AFFECT YOUR VIEW**

1501           **OF WHETHER THE COMMISSION SHOULD APPROVE THE**  
1502           **PROPOSED TARIFF?**

1503    A:    Yes, it is a significant development. The removal of the 2030 interim target gives  
1504           the Commission and Duke considerably more flexibility in how they structure  
1505           voluntary customer programs and in some ways makes those programs more  
1506           important than before. Previously, the near-term emissions reduction mandate  
1507           created pressure to count every clean resource toward Duke's own compliance  
1508           obligations, making it more difficult to designate customer-subscribed resources as  
1509           genuinely additional. With that constraint removed, the Commission has a clear  
1510           opportunity to approve a program in which customer resources are demonstrably  
1511           incremental to Duke's own procurement plans, advancing the clean energy goals of  
1512           participating customers without disrupting Duke's core planning obligations.  
1513           Duke's own reduced forecast procurements shows there is room for interconnecting  
1514           such customer projects, which would benefit the paying customer and the system at  
1515           large.

1516    **Q:    ARE THERE PRECEDENTS IN OTHER STATES FOR A PROGRAM**  
1517           **SIMILAR TO WHAT CEBA PROPOSES?**

1518    A:    Yes. CEBA's testimony highlights the Customer Identified Resource option  
1519           recently approved by the Georgia Public Service Commission within Georgia  
1520           Power's Clean and Renewable Energy Subscription program. That program allows  
1521           large customers to subscribe to specific clean energy resources procured by  
1522           Georgia Power on their behalf through power purchase agreements, with  
1523           subscribing customers paying the incremental cost and receiving bill credits based

1524 on avoided cost value. Multiple customers may also collaborate to subscribe to a  
1525 single resource. The Georgia experience demonstrates that a program of similar  
1526 design can be approved and implemented within a traditionally regulated utility  
1527 framework, and provides a useful model for the Commission's consideration in this  
1528 proceeding.

1529 **Q: WHAT IS THE BROADER SYSTEM BENEFIT OF DIRECTING DUKE**  
1530 **TO DEVELOP THE PROPOSED CLEAN CUSTOMER TARIFF?**

1531 A: The broader benefit is that the proposed tariff harnesses private capital from large  
1532 customers to expand clean energy deployment beyond what Duke would otherwise  
1533 plan, reducing the system's long-term dependence on gas-fired generation and the  
1534 fuel price risks that accompany it. Duke is currently projecting load growth of more  
1535 than 6,000 MW over its 15-year planning horizon and is proposing to meet a  
1536 substantial portion of that growth with nearly 10 GW of new gas-fired combined-  
1537 cycle and combustion turbine capacity. As discussed in my testimony above,  
1538 dependence on gas-fired generation leaves end customers exposed to gas price risk.  
1539 If large customers, many of whom are the very source of the forecast load growth,  
1540 can instead bring incremental clean resources to the system through CEBA's  
1541 proposed tariff, the need for some of that gas capacity may be reduced or deferred.  
1542 That outcome benefits all of Duke's customers, not just those that participate in the  
1543 program.

1544 **Q: WHAT DO YOU RECOMMEND THAT THE COMMISSION DO IN THIS**  
1545 **PROCEEDING?**

1546 A: I join CEBA in recommending the Commission find that the existing GSA Choice  
1547 program does not provide the additionality that large customers need and has  
1548 therefore largely failed to serve its intended purpose. I further recommend the  
1549 Commission to direct Duke to file an application for approval of a new clean  
1550 customer tariff for commercial and industrial customers consistent with the six  
1551 elements described in CEBA's testimony and endorsed in my testimony. The large  
1552 customers that CEBA represents are ready to deploy their capital to bring  
1553 additional clean energy resources to Duke's system. The Commission should give  
1554 them the program they need to do so.

1555 **Q: DOES THIS CONCLUDE YOUR TESTIMONY?**

1556 A: Yes.

1557